

STILL LINE SOP #50

LOCAL POWER FAILURE

CHECK	ACTION STEPS (All Caps)	COMMENTS (Below steps)
_____	1. BLOCK OFF STEAM TO STILLS (<u>CUT WAY BACK</u>).	
_____	2. PUT ALL STILLS ON RECYCLE.	
_____	3. BLOCK OFF NH ₃ TO NEUTRALIZERS.	
_____	4. BLOCK RECYCLES FCV.	
_____	5. BLOCK DISCHARGES ON PUMPS.	
_____	6. PUT FEED FLOW CONTROL VALVES AND REFLUX LCV ON MANUAL AND CLOSE BACK.	

CONFIDENTIAL:
Subject to Protective Order
of 14th Judicial District Court
No. 91-1145

SL 021104