

6 and 8. The recommended minimum inside dimensions and heights of chimneys for small and medium size installations are given in Table 1.

GENERAL EQUATION

The general draft equation for a steam producing plant may be stated as follows:

$$D_t - h_f = h_F + h_B + h_{Bd} + h_C + h_{Br} + h_V + h_O + h_E + h_R \quad (12)$$

where

- D_t = theoretical draft intensity created by pressure transformer, inches of water.
 h_f = draft loss due to friction in pressure transformer, inches of water.
 h_F = draft loss through the fuel bed, inches of water.
 h_B = draft loss through the boiler and setting, inches of water.
 h_{Br} = draft loss through the breeching, inches of water.
 h_V = draft loss due to velocity, inches of water.
 h_{Bd} = draft loss due to bends, inches of water.
 h_C = draft loss due to contraction of opening, inches of water.
 h_O = draft loss due to enlargement of opening, inches of water.
 h_E = draft loss through the economizer, inches of water.
 h_R = draft loss through recuperators, regenerators, or air heaters, inches of water.

The left hand member of Equation 12 represents the total amount of available draft created by the pressure transformer, that is, the natural draft chimney, Venturi chimney, or fan, and is equal to the theoretical intensity less the internal losses incidental to operation. The right hand member represents the sum of all of the various losses of draft throughout the entire boiler plant installation outside of the pressure transformer itself. The left hand member expresses the available intensity and is analogous to the head developed by a centrifugal pump in a water works system, while the right hand member expresses the required draft intensity and is analogous to the total dynamic head in a water works system. For a general circulation of gases

$$D_a = D_r \quad (13)$$

where

- D_a = available draft intensity, inches of water.
 D_r = required draft, inches of water.

The draft loss through the fuel bed (h_F), or the amount of draft required to effect a given or required rate of combustion, varies between wide limits and represents the greater portion of the required draft. In coal-fired installations, the draft loss through the fuel bed is dependent upon the following factors: (1) character and condition of the fuel, clean or dirty; (2) percentage of ash in the fuel; (3) volume of interstices in the fuel bed, coarseness of fuel; (4) thickness of the fuel bed, rate of combustion; (5) type of grate or stoker used; (6) efficiency of combustion.

There is a certain intensity of draft with which the best results will be obtained for every kind of coal and rate of combustion. Fig. 7 gives the intensity of draft, or the vacuum in the combustion chamber required to burn various kinds of coal at various rates of combustion. Expressed in

TABLE 1. RECOMMENDED MINIMUM CHIMNEY SIZES FOR HEATING BOILERS AND FURNACES^a

WARM AIR FURNACE CAPACITY IN SQ IN. OF LEADER PIPE	STEAM BOILER CAPACITY SQ FT. OF RADI- ATION	HOT WATER HEATER CAPACITY SQ FT. OF RADI- ATION	NOMINAL DIMEN- SIONS OF FIRE CLAY LINING IN INCHES	RECTANGULAR FLUE		ROUND FLUE		HEIGHT IN FT. ABOVE GRATE
				Actual Inside Dimensions of Fire Clay Lining in Inches	Actual Area Sq. In.	Inside Diam- eter of Lining in Inches	Actual Area Sq. In.	
790	590	973	8½ x 13	7 x 11½	81	10	79	35
1000	690	1,140	13 x 13	11¼ x 11¼	127			
	900	1,490	8½ x 18	6¾ x 16¾	110	12	113	40
	1,100	1,820	13 x 18	11¼ x 16¼	183	15	177	
	1,700	2,800	18 x 18	15¾ x 15¾	248			45
	1,940	3,200	20 x 20	17¼ x 17¼	298	18	254	50
	2,130	3,520				20	314	
	2,480	4,090	20 x 24	17 x 21	357			55
	3,150	5,200	24 x 24	21 x 21	441			60
	4,300	7,100		24 x 24 ^b	576	22	380	
	4,600	7,590				24	452	65
	5,000	8,250						
	5,570	9,190						
	5,580	9,200						
	6,980	11,500						
	7,270	12,000		24 x 28 ^b	672			
	8,700	14,400		28 x 28 ^b	784			
	9,380	15,500				27	573	
	10,150	16,750		30 x 30 ^b	900			
	10,470	17,250		28 x 32 ^b	896			

^aThis table is taken from the A.S.H.V.E. Code of Minimum Requirements for the Heating and Ventilation of Buildings (Edition of 1929).

^bDimensions are for unlined rectangular flues.

other words, these curves represent the amount of draft required to force the necessary amount of air through the fuel bed in order to effect various rates of combustion. It will be noted that the amount of draft increases as the percentage of volatile matter diminishes, being comparatively low for the lower grades of bituminous coals and highest for the high grades and small sizes of anthracites. Also, when the interstices of the coal are large and the particles are not well broken up, as with bituminous coals, much less draft is required than when the particles are small and are well broken up, as with bituminous slack and the small sizes of anthracites. In general, the draft loss through the fuel bed increases as: (1) the percentage of volatile matter diminishes; (2) the percentage of fixed carbon increases; (3) the thickness of the bed increases; (4) the percentage of ash increases; (5) the volume of the interstices diminishes.

In making the preliminary assumptions for the draft loss through the fuel bed, due allowances should be made for a possible future change in the grade of fuel to be burned and also in the rate of combustion. A value should be selected for this loss which will represent not only the highest rate of combustion which will be encountered, but also the grade of coal which has the greatest resistance through the fuel bed and which may be burned at a later date.

In powdered-fuel and oil-fired installations, there will be no draft loss