

be taken as equal to 95 per cent of the values given for the 18-in. pipe in Fig. 1.

In order to determine heat losses per linear foot of pipe from known losses per square foot, it is necessary to know the number of square feet area per linear foot of pipe. Table 2 gives these areas for various standard pipe sizes while Table 3 gives the area in square feet for flanges and fittings for various standard pipe sizes.

