

November 10, 1972

- 5) Consider relocating point of entry of make-up air - any dust that is not collected could be kept continually in motion by air sweeping up from the floor level;
- 6) Clean-up after day's operation or periodically throughout the day while dust controls are being improved upon;
- 7) Place plastic bag in disposal container - wet down waste pieces occasionally - when disposing of material, close top to prevent release of dust; and
- 8) Continue to require use of respirators on all jobs where asbestos materials are used, i.e. rip-out of old material, insulating, and fabricating (Rip-out requires use of air-supplied respirator.)

ORIGINAL SIGNED BY

RICHARD J. HUBIAR

RICHARD J. HUBIAR
INDUSTRIAL HYGIENIST

RJH/nsh
Attachment

DUP 0903039