



UNDERWRITERS' LABORATORIES, INC.

333 PFINGSTEN ROAD - NORTHBROOK, ILLINOIS 60062

an independent, not-for-profit organization testing for public safety

WRG 000229

January 5, 1972



R4339

7088272

Mr. Thomas P. Feit - Manager
Technical Services
Zonolite Construction Products Div.
W. R. Grace & Co.
62 Whittemore Avenue
Cambridge, Mass. 02140

Subject: R4339
MK4-Floor Ceiling Design No. 205-3 Hr.

Dear Mr. Feit:

This will confirm that Mono Kote 4 is acceptable for use in Floor and Ceiling Design No. 205-3 Hr, as described on Page 280 of the January 1971 "Building Materials List," with the following changes:

- 1) Item 1 - as an alternate to the described regular weight concrete, lightweight concrete may be used.
- 2) Item 3 - the description under "Steel Floor Units" is applicable except for the last sentence. That is the floor may not be composed of all cellular units.
- 3) Item 8 - as an alternate to the presently described Mono Kote 3, the asbestos free Mono Kote 4 may be used applied at a minimum average (dry) density of 20 pcf with minimum individual density of 18 pcf.

Very truly yours,

Robert M. Berhinig

ROBERT M. BERHINIG
Engineering Group Leader
Fire Protection Department

RMB:jb

25049943