



June 30, 1980

cc: Acc. Prev. &
Occu. Health -
General Office
R. J. Bendure
S. A. Gunderson
(Houston)
H. H. Lawson/
IH Staff

To: B. A. Rogers
Safety Engineer
Houston Works

From: J. W. Frazee

Subject: Industrial Hygiene -
Identification of
Insulating Materials -
Houston Works



SI-80302, Report No. 1 - Final

Three samples of old insulating materials were submitted to determine if they contained asbestos.

X-ray diffraction showed the samples numbered #1 and #2 contain chrysotile. Asbestos was not found in sample #3.

Jerry W. Frazee

Jerry W. Frazee
Chemist
Chemical Technology
Research & Technology

jn

REFERENCE: Research Daybook 5055, p. 49

ARM 874

ARM000016



cc: Acc. Prev. &
Occu. Health -
General Office
R. J. Bendure
~~S. A. Gundersen~~
~~(Houston)~~
H. H. Lawson/
IH Staff

June 30, 1980

To: B. A. Rogers
Safety Engineer
Houston Works

From: J. W. Frazee

Subject: Industrial Hygiene -
Identification of
Insulating Materials -
Houston Works

SI-80302, Report No. 1 - Final

Three samples of old insulating materials were submitted to determine if they contained asbestos.

X-ray diffraction showed the samples numbered #1 and #2 contain chrysotile. Asbestos was not found in sample #3.

Jerry W. Frazee
Chemist
Chemical Technology
Research & Technology

jn

REFERENCE: Research Daybook 5055, p. 49

ARM 931

ARM000062