TM-10
MCC 950920

Monsanto

PLAINTIFF'S EXHIBIT
MON-1962

FROM (NAME & LOCATION) R. T. Hammann - Texas City, LP&S, O-22 (Ext. 3234)

April 24, 1984

SUBJECT: 1st Quarter Safety & Housekeeping Inspection - Dept. 48/56

REFERENCE:

TO: J. T. Shipley 56D
V. Fields 56D

cc: SHAC
E. H. Dowden SS-14
P. K. Saunders ED
J. Gaviria 56D
R. D. Coleman 56D
H. M. Lacy O-6
J. G. Trafton O-6

The 1st Quarter Safety & Housekeeping Inspection for Dept. 48/56 was conducted on April 17, 1984 by the inspection team of Ed Dowden, Paul Saunders and Bob Hammann. Overall, the area was found to be in good condition.

The following are specific items that need attention:

Safety

1. Need to formalize safety meetings and start holding them.
2. Change out safety shower and eyebath signs on the top deck of Dept. 56.
3. Five-minute escape mask low on first deck of Dept. 48 reactor area.
4. Replace sign at utility water station by 48E508.
5. Safety chain needed on chain operated valve by 48T503.
6. Electrical outlet being used for fan near filter precoat area in Dept. 56 west side. Needs to be moved - interferes with safety shower area.
7. Get rid of old CED stepladder by 56T10 - poor condition.

Housekeeping

1. Scaffold storage areas need clean up: (a) by Dept. 48 fin fan area, (b) by 48T13-2.
2. Need better storage for water bottles and equipment in breaker room by storage batteries. Also there are miscellaneous electrical materials in the breaker room.

Please respond to these comments in writing to J. G. Trafton with carbon copy to Steve Moncla by May 15, 1984.

R. T. Hammann

/dgb