



REGION 8
1595 Wynkoop Street
Denver, CO 80202-1129

September 18, 2024

SENT VIA EMAIL

Ref: 8WD-SDR

Hagens Estates
c/o Alan Klitz
4 Emily Court
Gillette, Wyoming 82718
alan.klitz@yahoo.com

Re: Notice of Noncompliance
Revised Total Coliform Rule (RTCR)
Failure to Submit Sample Siting Plan
PWS ID# WY5601739 C

Dear Alan Klitz:

The purpose of this letter is to inform you that Hagens Estates failed to submit a Sample Siting Plan as required by the Revised Total Coliform Rule by April 1, 2016. A Sample Siting Plan indicates where you will collect your total coliform samples to ensure the safety of the water you supply to the public. Per 40 C.F.R. § 141.853 of the National Primary Drinking Water Regulations (NPDWR) all public water systems were required to develop or revise a written Sample Siting Plan and submit it to the EPA by April 1, 2016. EPA Region 8 requested that you submit a Sample Siting Plan by **August 19, 2024**. The EPA has not received a Sample Siting Plan.

If not already done, please complete the following actions:

- (1) If you completed the Sample Siting Plan, please forward the plan to our office.
- (2) If you have not created a Sample Siting Plan, please use the template at the following website (<https://www.epa.gov/region8-waterops/revised-total-coliform-rule>) and forward the Sample Siting Plan to EPA Region 8 no later than 30 days from receipt of this letter.

Please submit your Sample Siting Plan to EPA Region 8 using one of the methods listed below. Include your PWS name and PWS ID # on all correspondence.

Email: R8DWU@epa.gov

Fax: 1-877-876-9101

Mail: Refer to the address at the top of this letter. Use Mail Code 8WD-SDR on the envelope.

You should be aware that repeated violations of the National Primary Drinking Water Regulations may result in formal enforcement action taken against your water system. If formal enforcement action becomes necessary, the Safe Drinking Water Act provides for civil penalties of up to \$69,733 per day of violation. We prefer to address problems before such formal enforcement is necessary and ask for your cooperation to resolve problems quickly and effectively.

If you have any questions, please contact Jamie Harris at 303-312-6072 or by email at harris.jamie@epa.gov.

Sincerely,

**SETH
TOURNEY**

Seth Tourney, P.E.

Supervisor, Rule Implementation Section
Drinking Water Program

Digitally signed by SETH
TOURNEY
Date: 2024.09.18 10:33:03
-06'00'