

WILLARD C. DIXON

DIXON INFORMATION INC.

MICROSCOPY, ASBESTOS ANALYSIS & CONSULTING

A.I.H.A. ACCREDITED LABORATORY #10847

NVLAP CODE 1012

September 5, 1995

ASARCO
3422 South 700 West
Salt Lake City, Utah 84119

Ref: Batch #32172, Lab #A20775
Received September 1, 1995
P.O. # B094-1681
Bulk asbestos sample

Sample A20775 has been analyzed by visual estimation based on EPA-600/M4-82-020 Dec. 1982 optical microscopy test method including phase contrast, polarized light, dispersion staining, and stereo microscopy.

If this sample is related to a demolition or is subject to NESHAPS 40CFR part 61 regulations, these regulations mandate that any sample containing less than 1% asbestos must be analyzed by point count. If asbestos is reported to be between 1% and 10%, see EPA "Clarification of asbestos NESHAP requirements to perform point counting." (Copy available.)

This report relates only to the items tested. This report must not be used to claim product endorsement by the NVLAP, the National Institute of Standards and Technology, or any agency of the U. S. Government. The results of analysis are as follows:

Lab A20775, Field L951903-1 Bulk asbestos sample
This is 70% chrysotile asbestos in gray binder with rust and sand.

Very truly yours,

_Date: September 5, 1995

78 WEST 2400 SOUTH SOUTH SALT LAKE, UTAH 84115-3013

(801) 486-0800

Res. (801) 278-4521

ASARCO ELP 0014974