

KINSTON
INSULATION TRAINING MANUAL

BOOK 2

CONTENTS

SECTION V - APPLICATION - PIPE

1. Quality of application
2. Sequence of application
- A. HI-TEMP. - +75°F TO 650°F
 1. Calcium silicate
 - A. Single layer -
 - B. Double layer

SECTION VI - FINISHES

- A. HI-TEMP - INDOOR
 1. 8 oz. canvas +75°F to 350°F
 2. 8 oz. canvas 350°F to 650°F
 3. Hypalon® laminate +75°F to 350°F
 4. "Hypalon" laminate 350°F to 650°F
- HI-TEMP - OUTDOOR
 5. "Hypalon" laminate +75°F to 350°F
 6. "Hypalon" laminate 350°F to 650°F