

TO: OM HAZOP TEAM

FROM: J.B. AUTREY  
DATE: August 5, 1995

Interoffice  
Communication

VISTA


SUBJECT: OM HAZOP Hazard OM-94001

Equipment Description: Fresh VCM Receiver

Suggested Mitigation: PREVENTIVE MAINTENANCE ON LEVEL  
INSTRUMENTS.

Resolution: An annual PM is set up in VMS on all critical level instrumentation.  
The fresh receiver is included in this.

If you have any questions, please contact me.



Jimmy Autrey  
Maintenance Manager - Aberdeen  
psmres01

c: SJV,TJS,MLC