



REGION 10
SEATTLE, WA 98101

October 28, 2024

Mr. David Lucas
Makah Tribe
P.O. Box 115
Neah Bay, WA 98357

Maximum Contaminant Level (MCL) Violation: Exceedance of Total Trihalomethanes (TTHM) Disinfection Byproduct, Makah Neah Bay, PWS ID 105300012

Dear Mr. Lucas:

The purpose of this letter is to inform Makah Neah Bay of two total trihalomethanes (TTHM) disinfection byproduct maximum contaminant level (MCL) exceedances, which constitute violations of the National Primary Drinking Water Regulations [40 CFR 141.625(b)]. All community and non-transient non-community public water systems that disinfect are required to monitor drinking water to determine compliance with the MCL of 0.080 mg/L for TTHM [40 CFR 141.620(b)]. Compliance with the TTHM MCL is determined by calculating a running annual average of the samples collected in the four most recent quarters [40 CFR 141.620(d)]. The running annual average value of TTHM at sample site ID S-10 as of the 4/1/2024 – 6/30/2024 compliance period is 0.081 mg/L.

Compliance Period	Collection Date	TTHM Result (mg/L)
4/1/2024 – 6/30/2024	4/15/2024	0.0998
1/1/2024 – 3/31/2024	1/29/2024	0.0759
10/1/2023 – 12/31/2023	11/6/2023	0.120
7/1/2023 – 9/30/2023	8/2/2023	0.030
Running Annual Average		0.081

The running annual average value of TTHM at sample site ID S-10 as of the 7/1/2024 - 9/30/2024 compliance period is 0.099 mg/L.

Compliance Period	Collection Date	TTHM Result (mg/L)
7/1/2024 – 9/30/2024	No sample	No sample
4/1/2024 – 6/30/2024	4/15/2024	0.0998
1/1/2024 – 3/31/2024	1/29/2024	0.0759
10/1/2023 – 12/31/2023	11/6/2023	0.120
Running Annual Average		0.099

To return to compliance Makah Neah Bay must:

1. Continue to collect a TTHM sample the first month of every quarter from sample site ID S-10 and submit sample results to R10TribalDW@epa.gov.

-AND-

2. Have a running annual average below the TTHM MCL of 0.080 mg/L at sample site ID S-10.

Additionally, Makah Neah Bay must:

1. Distribute Tier 2 Public Notification (PN) **within 30 days** of receiving this letter and **every three months afterwards** until the violation has returned to compliance [[40 CFR 141.203\(b\)](#)].

-AND-

2. Submit a copy of the PN that was distributed and the completed PN Certification Form to R10TribalDW@epa.gov within 10 days after issuing the notice [[40 CFR 141.31\(d\)\(1\)](#)].

A Public Notification template, instructions, and certification are enclosed to assist with completing the requirements.

This letter serves as initial notification of non-compliance under the Safe Drinking Water Act for the regulation and time period cited. The Environmental Protection Agency (EPA) supports compliance assistance and encourages early action to return to compliance. Issues not addressed in a timely manner may be referred to enforcement. Prior to an enforcement action for the cited violation(s), EPA Region 10 will offer government-to-government consultation, in accordance with the [EPA Policy on Consultation and Coordination with Indian Tribes](#).

A list of all violations and their status can be viewed at any time by visiting Drinking Water Watch: <https://sdwisdww.epa.gov/DWWR10/>. Please contact R10TribalDW@epa.gov with questions.

Sincerely,

CHRISTOPHER AFFELDT
Digitally signed by
CHRISTOPHER AFFELDT
Date: 2024.10.28
11:36:26 -07'00'

Chris Affeldt
Acting Manager
Groundwater and Drinking Water Section

cc: Glenn Lucas, Makah Tribe
Henry Cross, Sr., Makah Tribe
Sandy Redsteer, Indian Health Service

Instructions for TTHM MCL Violation Public Notice

If your system's locational running annual average for Total Trihalomethanes (TTHM) exceeds the MCL of 0.080 mg/L at one or more sampling locations, you must provide Tier 2 public notification to persons served as soon as practical but within 30 days after you learn of the violation [\[40 CFR 141.203\(b\)\]](#). Check with your primacy agency to make sure you meet its requirements.

Community systems must use one of the following [\[40 CFR 141.203\(c\)\]](#):

- Hand or direct delivery
- Mail, as a separate notice or included with the bill
- Another method approved in writing by the EPA

Non-community systems must use one of the following [\[40 CFR 141.203\(c\)\]](#):

- Posting in conspicuous locations
- Hand delivery
- Mail
- Another method approved in writing by the EPA

In addition, both community and noncommunity systems must use another method reasonably calculated to reach others if they would not be reached by the first method [\[40 CFR 141.203\(c\)\]](#). Such methods could include newspapers, e-mail, or delivery to community organizations. If you mail, post, or hand deliver, print your notice on your system's letterhead, if available.

The following notice is appropriate for is appropriate for mailing, posting, or hand delivery. If you do modify the notice, you must still include all required PN elements from [40 CFR 141.205\(a\)](#) and leave the mandatory language unchanged (see below).

Mandatory Language

Mandatory language on health effects (from [Appendix B to 40 CFR 141 Subpart Q](#)) must be included as written (with blanks filled in) and is presented in this notice in italics and with an asterisk on either end.

You must also include standard language to encourage the distribution of the public notice to all persons served, where applicable [\[40 CFR 141.205\(d\)\]](#). This language is also presented in this notice in italics and with an asterisk on either end.

Corrective Action

In your notice, describe corrective actions you are taking. Listed below is one step commonly taken by water systems with TTHM MCL violations. You can include the following statement, if appropriate, or develop your own text:

- We are working to minimize the formation of TTHM while ensuring we maintain an adequate level of disinfectant. We have taken additional steps to change disinfectant type/levels, remove natural organic matter, and increased flushing of water lines to determine if our efforts have been effective.

After Issuing the Notice

Make sure to send your primacy agency a copy of each type of notice and a certification that you have met all the public notice requirements within ten (10) days after issuing the notice [\[40 CFR 141.31\(d\)\]](#).

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Total Trihalomethanes (TTHM) Maximum Contaminant Level Exceedance

Public Water System: Makah Neah Bay Date distributed: _____

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Total Trihalomethanes (TTHM) are four chemicals that form when disinfectants react with natural organic matter in the water. On ____ / ____ / ____, we received notice that the average concentration of TTHM for the 4/1/2024 – 6/30/2024 compliance period was 0.081 mg/L, and for the 7/1/2024 – 9/30/2024 compliance period was 0.99 mg/L. **This is above the TTHM maximum contaminant level (MCL) of 0.080 mg/L.** The average concentration is determined by averaging all the samples for the past 12 months.

What does this mean?

People who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your healthcare providers about drinking this water.

What is being done?

We anticipate resolving the problem within a _____ time frame by doing the following:

_____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Contact Person: _____ Phone: _____

EPA Region 10 Tier 2 Public Notification Certification Form

Public Water Systems must provide initial Tier 2 public notice as soon as practical, but no later than **30 days** after EPA's Notice of Violation Letter. You must repeat Tier 2 public notices **every three months** until the violation has returned to compliance.

Complete the section which corresponds to your water system type.

Community Water Systems:

☐ Public notice mailed or directly delivered to all consumers receiving water within the form, manner and frequency required in [40 CFR 141.203](#).

Provide information of another method used to reach others regularly served if they would not normally be reached by the method above. Such methods could include posting in public places or internet, newspapers, email, social media, delivery to community organizations, etc.

Describe alternate method:

Non-Community Water Systems:

☐ Public notice posted at _____ within the form, manner and frequency required in [40 CFR 141.203](#).

Provide information of another method used to reach others served if they would not normally be reached by the method above. Such methods could include mail, posting on the internet, newspapers, email, social media, delivery to community organizations, etc.

Describe alternate method:

I hereby affirm that public notice has been provided to consumers in accordance with the delivery, content, format, and deadlines required in [40 CFR Part 141 Subpart Q](#).

Makah Neah Bay
Water System Name

105300012
PWS ID#

Signature

Date

Email a copy of the public notice and this certification form within **10 days** of completing initial public notice or any repeat public notice to: R10TribalDW@epa.gov