

OF TRANSFORMER

67346 15

TC NUMBER 28

Don Name or Number

Spare



☒ Indoor

☒ Outdoor

☐ Roof

☒ Ground

☐ Platform

☐ Pole

Unit Or Tag Number

NAMEPLATE INFORMATION

Manufacturer General Electric Primary Volts 13200 Gal. 250 ☐ Oil ☒ Askarel
 Serial Number H888710 Secondary Volts 480Y/277 Impedance 5.47
 KVA Rating 2000 Phase/Cycle 3/60 Other

Liquid Level N Radiators ☒ Yes ☐ No Conservator Tank ☐ Yes ☒ No Top Valve 1"
 Temperature 24 Fans ☐ Yes ☒ No Tap Changer Comp. ☐ Yes ☒ No Bottom Valve 1"
 Pressure/Vacuum +2 1/2 H₂O Cooled ☐ Yes ☒ No Bushings: ☐ Top ☒ Side Other Access

ReR Hose 3ø Pwr. On Al Pwr. Off OT

TRANSFORMER LIQUID TEST DATA

	DATE	PO #	SERVICED	DIEL	ACID	RESIST	COLOR	SPECIFIC GRAVITY	VISUAL	LEAKS	PAINT	OIL CLASS	RECOMMEND
1	6/76	Per 3SA	Tested	36	0.01	N/A	Grn	1.540	Clr	None	Good	Good	Retest 1 yr
2	10/77	Per 3SA	Tested	49	0.01	N/A	P/G	1.490	Clr	None	Good	Good	Retest 1 yr
3	6-78	PS74463	Tested	46	0.01	N/A	P/G	1.480	Clr	None	Good	Good	Retest 1 yr
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													

0497431

transformer

Div. of S. D. MYERS, INC.
 P.O. Box 3575, Akron, Ohio 44310 Phone (216) 929-2847

consultants

PCB-ARCH0744763