

lengths and mean velocities of flow as a circular duct of the same hydraulic diameter. When duct sizes are expressed in terms of hydraulic diameter, and when equations for friction loss in round and rectangular ducts are equated for equal capacity and equal length, an equation giving the circular equivalent of a rectangular duct is obtained* (Equation 3).

$$d_c = 1.30 \frac{(ab)^{0.625}}{(a+b)^{0.625}} = 1.30 \sqrt[0.625]{\frac{(ab)^2}{(a+b)^2}} \quad (3)$$

where

- a = length of one side of rectangular duct, inches. (Other side is b)
 b = length of one side of rectangular duct, inches. (Other side is a)
 d_c = circular equivalent of a rectangular duct for equal friction and capacity, inches.

Table 2 gives the circular equivalents of rectangular ducts for equal friction and capacity for aspect ratios not greater than 11.7:1 based on Equation 3.⁵

Multiplying or dividing the length of each side of a duct by a constant is the same as multiplying or dividing the equivalent round size by the same constant. Thus, if the circular equivalent of an 80 x 24 in. duct is required, it will be twice that of 40 x 12 in. duct, or 2 x 23.0 = 46.0 in.

DYNAMIC LOSSES

Wherever eddying flow is present, brought about by sudden changes in the direction or magnitude of the velocity of the air flowing, a greater loss in pressure takes place than would occur in a steady flow through a similar length of straight duct having a uniform cross-section. The amount of this loss, in excess of straight duct friction, is termed *dynamic loss*. Dynamic losses generally are greater with decelerating flow in duct enlargements than with accelerating flow in reducing fittings. Although dynamic

TABLE 2. CIRCULAR EQUIVALENTS OF RECTANGULAR DUCTS FOR EQUAL FRICTION AND CAPACITY
Dimensions in Inches

SIDE RECTAN- GULAR DUCT	4.0	4.5	5.0	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
3.0	3.8	4.0	4.2	4.4	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.6	5.7
3.5	4.1	4.3	4.6	4.8	5.0	5.2	5.3	5.5	5.7	5.8	6.0	6.1	6.3
4.0	4.4	4.6	4.9	5.1	5.3	5.5	5.7	5.9	6.1	6.3	6.4	6.6	6.8
4.5	4.6	4.9	5.2	5.4	5.6	5.9	6.1	6.3	6.5	6.7	6.9	7.0	7.2
5.0	4.9	5.2	5.5	5.7	6.0	6.2	6.4	6.7	6.9	7.1	7.3	7.4	7.6
5.5	5.1	5.4	5.7	6.0	6.3	6.5	6.8	7.0	7.2	7.4	7.6	7.8	8.0

SIDE RECTAN- GULAR DUCT	10.0	10.5	11.0	11.5	12.0	12.5	13.0	13.5	14.0	14.5	15.0	15.5	16.0
3.0	5.7	5.9	6.0	6.1	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9	7.0
3.5	6.3	6.4	6.5	6.7	6.8	6.9	7.0	7.1	7.2	7.3	7.4	7.5	7.6
4.0	6.8	6.9	7.1	7.2	7.3	7.5	7.6	7.7	7.8	7.9	8.1	8.2	8.3
4.5	7.2	7.4	7.5	7.7	7.8	8.0	8.1	8.2	8.4	8.5	8.6	8.7	8.9
5.0	7.6	7.8	8.0	8.1	8.3	8.4	8.6	8.7	8.9	9.0	9.1	9.3	9.4
5.5	8.0	8.2	8.4	8.6	8.7	8.8	9.0	9.2	9.4	9.5	9.6	9.8	9.8

TABLE 2. CIRCULAR EQUIVALENTS OF RECTANGULAR DUCTS FOR EQUAL FRICTION AND CAPACITY (CONTINUED)

Dimensions in Inches

SIDE RECTAN- GULAR DUCT	6	7	8	9	10	11	12	13	14	15	16	17	18	19
6	6.6													
7	7.1	7.7												
8	7.5	8.2	8.8											
9	8.0	8.6	9.3	9.9										
10	8.4	9.1	9.8	10.4	10.9									
11	8.8	9.5	10.2	10.8	11.4	12.0								
12	9.1	9.9	10.7	11.3	11.9	12.5	13.1							
13	9.5	10.3	11.1	11.8	12.4	13.0	13.6	14.2						
14	9.8	10.7	11.5	12.2	12.9	13.5	14.2	14.7	15.3					
15	10.1	11.0	11.8	12.6	13.3	14.0	14.6	15.3	15.8	16.4				
16	10.4	11.4	12.2	13.0	13.7	14.4	15.1	15.7	16.3	16.9	17.5			
17	10.7	11.7	12.5	13.4	14.1	14.9	15.5	16.1	16.8	17.4	18.0	18.6		
18	11.0	11.9	12.9	13.7	14.5	15.3	16.0	16.6	17.3	17.9	18.5	19.1	19.7	
19	11.2	12.2	13.2	14.1	14.9	15.6	16.4	17.1	17.8	18.4	19.0	19.6	20.2	20.8
20	11.5	12.5	13.5	14.4	15.2	15.9	16.8	17.5	18.2	18.8	19.5	20.1	20.7	21.3
22	12.0	13.1	14.1	15.0	15.9	16.7	17.6	18.3	19.1	19.7	20.4	21.0	21.7	22.3
24	12.4	13.6	14.6	15.6	16.6	17.5	18.3	19.1	19.8	20.6	21.3	21.9	22.6	23.2
26	12.8	14.1	15.2	16.2	17.2	18.1	19.0	19.8	20.6	21.4	22.1	22.8	23.5	24.1
28	13.2	14.5	15.6	16.7	17.7	18.7	19.6	20.5	21.3	22.1	22.9	23.6	24.4	25.0
30	13.6	14.9	16.1	17.2	18.3	19.3	20.2	21.1	22.0	22.9	23.7	24.4	25.2	25.9
32	14.0	15.3	16.5	17.7	18.8	19.8	20.8	21.8	22.7	23.6	24.4	25.2	26.0	26.7
34	14.4	15.7	17.0	18.2	19.3	20.4	21.4	22.4	23.3	24.2	25.1	25.9	26.7	27.5
36	14.7	16.1	17.4	18.6	19.8	20.9	21.9	23.0	23.9	24.8	25.8	26.6	27.4	28.3
38	15.0	16.4	17.8	19.0	20.3	21.4	22.5	23.5	24.5	25.4	26.4	27.3	28.1	29.0
40	15.3	16.8	18.2	19.4	20.7	21.9	23.0	24.0	25.1	26.0	27.0	27.9	28.8	29.7
42	15.6	17.1	18.5	19.8	21.1	22.3	23.4	24.5	25.6	26.6	27.6	28.5	29.4	30.4
44	15.9	17.5	18.9	20.2	21.5	22.7	23.9	25.0	26.1	27.2	28.2	29.1	30.0	31.0
46	16.2	17.8	19.2	20.6	21.9	23.2	24.3	25.5	26.7	27.7	28.7	29.7	30.6	31.6
48	16.5	18.1	19.6	20.9	22.3	23.6	24.8	26.0	27.2	28.2	29.2	30.2	31.2	32.2
50	16.8	18.4	19.9	21.3	22.7	24.0	25.2	26.4	27.6	28.7	29.8	30.8	31.8	32.8
52	17.0	18.7	20.2	21.6	23.1	24.4	25.6	26.8	28.1	29.2	30.3	31.4	32.4	33.4
54	17.3	19.0	20.5	22.0	23.4	24.8	26.1	27.3	28.5	29.7	30.8	31.9	32.9	33.9
56	17.6	19.3	20.9	22.4	23.8	25.2	26.5	27.7	28.9	30.1	31.2	32.4	33.4	34.5
58	17.8	19.5	21.1	22.7	24.2	25.5	26.9	28.2	29.3	30.5	31.7	32.9	33.9	35.0
60	18.1	19.8	21.4	23.0	24.5	25.8	27.3	28.7	29.8	31.0	32.2	33.4	34.5	35.5
62	18.3	20.1	21.7	23.3	24.8	26.2	27.6	29.0	30.2	31.4	32.6	33.8	35.0	36.0
64	18.6	20.3	22.0	23.6	25.2	26.5	27.9	29.3	30.6	31.8	33.1	34.2	35.5	36.5
66	18.8	20.6	22.3	23.9	25.5	26.9	28.3	29.7	31.0	32.2	33.5	34.7	35.9	37.0
68	19.0	20.8	22.5	24.2	25.8	27.3	28.7	30.1	31.4	32.6	33.9	35.1	36.3	37.5
70	19.2	21.	22.8	24.5	26.1	27.6	29.1	30.4	31.8	33.1	34.3	35.6	36.8	37.9

losses may be assumed to be caused by changes in area actually occupied by the air flow, for convenience they are divided into two general classes: (1) those caused by *changes in direction* of the duct at bends and branches, and (2) those caused by *changes in cross-sectional area* of the duct at transitions.

Dynamic losses vary substantially as the square of the mean velocity of