

burners was developed for the Institute of Cooking and Heating Appliance Manufacturers by R. N. St. John. A glass rod is interposed between a light source and a photo-sensitive cell, both before and after being exposed to the flue gases from a heating device. The diminution of the light transmitted by the rod, due to the deposit of soot on its surface, causes a reduction in the cell emf which is taken as an index of the concentration of smoke in the flue gases. A description of the method is contained in *National Bureau of Standards Commercial Standard CS104-46*.⁶

DETERMINATION OF AIR CONTAMINANTS

Two measures of air dustiness are in use: particles per unit volume of air, and weight per unit volume of air. A comparative method consists in drawing known samples of air through a known area of filter cloth or paper, and comparing the density of the resulting spots with blackness charts or with spots from other sources.

For counting, particles are captured in a device such as the Smith-Greenburg impinger, the Owens jet dust counter, or in an electrostatic or a thermal precipitation device designed for the purpose.⁷ Counting is done with a microscope, and the method yields important results when the nature or constituents of the dust are of interest.

For a weight determination, a known volume of air is drawn through a porous crucible or thimble, and the weight gained by the thimble during the operation is the weight of the dust captured from the air sample.⁸ For precise work, the thimble must be dried in a desiccating chamber before weighing each time.

At the National Bureau of Standards a test method was developed for interested Government agencies, under which measured samples of the uncleaned air and of the air cleaned by a device under test are passed through filter papers.⁹ The ratio of the flow rates through the two filter papers is adjusted during successive tests, until the resulting dust spots approach equality in density as shown by a photometer. The ratio of the flow rates is then indicative of the effectiveness of the cleaner in arresting dust. A statement of an air cleaner's efficiency by any test method, is meaningless unless the test dust is specified. Other instruments for determining gaseous and particulate air contaminants are described in industrial hygiene literature.^{10, 11, 12}

SOUND AND VIBRATION MEASUREMENTS^{13, 14, 15, 16}

The measurement, analysis, and ultimate control of noise in air-conditioning systems is becoming increasingly important. The sound-level meter is the basic instrument used in acoustic measurements. While a crystal-type microphone is usually supplied with the meter, dynamic and condenser-type microphones can also be used. The dynamic type is employed when the microphone and sound-level meter are separated by a long cable. The condenser microphone is stable and has a flat response. Crystal microphones are stable and sensitive, but require a temperature correction when connected to the sound-level meter through a long cable.

In the refined art of acoustics, the overall or total sound level is of little value. Loudness and annoyance as interpreted by the ear are a function of frequency as well as sound level. The effective rating and control of noise must, therefore, involve the measurement of frequency distribution. The octave-band analyzer, which divides the noise

spectrum into eight frequency bands, is most commonly used in conjunction with the sound-level meter. A number of the criteria that have been developed for environmental noise levels are based on octave bands. Narrow-band filters are also available, and impact noise analyzers can be used to measure transient noise levels such as those produced by drop-forge hammers.

Electronic instruments are available for measuring the frequency, amplitude, and acceleration of a vibrating mass. Vibration meters are usually portable, self-contained, and direct reading.

REFERENCES

- ¹For a comprehensive treatment of temperature measurement the reader is referred to *Temperature, Its Measurement and Control in Science and Industry* (Symposium of American Institute of Physics, published by Reinhold Publishing Corp., New York).
- ²H. D. Baker, E. A. Ryder, and N. H. Baker: *Temperature Measurement in Engineering* (John Wiley and Sons, New York).
- ³Temperature measurement (ASME Power Test Code, Part 3).
- ⁴G. V. Parmelee and R. G. Huebner: ASHVE RESEARCH REPORT No. 1292—The shielding of thermocouples from the effects of radiation (ASHVE TRANSACTIONS, Vol. 52, 1946, p. 183).
- ⁵P. Nicholls and W. E. Rice: Errors in the measurement of the temperature of flue gases (ASHVE TRANSACTIONS, Vol. 35, 1929, p. 473).
- ⁶A. C. Willard, A. P. Kratz, and V. S. Day: *Investigation of Warm Air Furnaces and Heating Systems* (Illinois Engineering Experiment Station Bulletin No. 120).
- ⁷P. Nicholls: Measuring heat transmission in building structures and a heat transmission meter (ASHVE TRANSACTIONS, Vol. 30, 1924, p. 94).
- ⁸W. B. Kirk and G. J. Pacanovsky: Parallel-connected thermocouples for the testing of gas appliances (Gas, September 1939, p. 51).
- ⁹American Standard for Indicating Pressure and Vacuum Gages, Round Dial Type, with Elastic Pressure Chamber (American Standards Association, B. 40.1—1939).
- ¹⁰Standard Test Code for Centrifugal and Axial Fans (ASHVE and NAFM, published as NAFM Bulletin No. 110, 1938).
- ¹¹Fan Engineering (Buffalo Forge Company, Buffalo, New York, 5th ed., p. 165).
- ¹²Illinois Micromanometer (University of Illinois, Engineering Experiment Station Bulletin No. 120, p. 91).
- ¹³J. E. Enswiler and W. C. Randall: The weathertightness of rolled steel windows (ASHVE TRANSACTIONS, Vol. 34, 1928, p. 527).
- ¹⁴Psychrometric Tables for Vapor Pressure, Relative Humidity and Temperatures of the Dew-Point (U. S. Department of Agriculture, Weather Bureau).
- ¹⁵For technical data refer to *Fluid Meter Reports* (American Society of Mechanical Engineers, Parts 1—1937, 2—1931, and 3—1933).
- ¹⁶National Advisory Committee for Aeronautics Technical Notes No. 546 (November 1935).
- ¹⁷F. R. Ingram, E. Dix-Caneeco, and L. Silverman: The characteristics of double Pitot tubes (ASHVE JOURNAL SECTION, Heating, Piping and Air Conditioning, November 1942, p. 708).
- ¹⁸H. S. Bean, E. Buckingham, and P. S. Murphy: Discharge coefficients of square edged orifices for measuring the flow of air (Bureau of Standards Journal of Research, Vol. 2, 1929, p. 561).
- ¹⁹Flow measurement by nozzles and orifice plates (ASME Power Test Codes, 1949, Part 5 of Chapter 4).

Instruments and Measurements

- ²⁰Pressure measurement (ASME Power Test Code, 1936, Part 2 of Chapter 2).
- ²¹D. D. Wile: Air flow measurement in the laboratory (Refrigerating Engineering, June 1947, p. 515).
- ²²G. L. Tuve, G. B. Priestner, and D. K. Wright, Jr.: ASHVE RESEARCH REPORT No. 1204—Entrainment and jet-pump action of air streams (ASHVE TRANSACTIONS, Vol. 48, 1942, p. 241).
- ²³A. P. Kratz, A. E. Hershey, and R. B. Engdahl: ASHVE RESEARCH REPORT No. 1165—Development of instruments for the study of air distribution in rooms (ASHVE TRANSACTIONS, Vol. 46, 1940, p. 351).
- ²⁴D. D. Wile: Development of testing apparatus for thermostats (ASHVE TRANSACTIONS, Vol. 42, 1936, p. 349).
- ²⁵J. F. Kemp: Stable hot-wire anemometer for low speeds (ASHAE JOURNAL SECTION, Heating, Piping and Air Conditioning, October 1957, p. 137).
- ²⁶C. P. Yaglou: The heated thermometer anemometer (Journal of Industrial Hygiene and Toxicology, Vol. 20, October 1938).
- ²⁷H. B. Nottage: A simple heated-thermocouple anemometer (ASHVE TRANSACTIONS, Vol. 56, 1950, p. 431).
- ²⁸L. E. Davies: ASHVE RESEARCH REPORTS Nos. 857, 911, and 966—Measurement of the flow of air through registers and grilles (ASHVE TRANSACTIONS, Vol. 36, 1930, p. 201; Vol. 37, 1931, p. 619; and Vol. 39, 1933, p. 373).
- ²⁹G. L. Tuve and D. K. Wright, Jr.: ASHVE RESEARCH REPORT No. 1162—Air flow measurements at intake and discharge openings and grilles (ASHVE TRANSACTIONS, Vol. 46, 1940, p. 313).
- ³⁰A. M. Greene, Jr. and M. H. Dean: ASHVE RESEARCH REPORT No. 1092—The flow of air through exhaust grilles (ASHVE TRANSACTIONS, Vol. 44, 1938, p. 387).
- ³¹G. L. Larson, D. W. Nelson, and R. W. Kubasta: ASHVE RESEARCH REPORT No. 836—Investigation of air outlets in class room ventilation (ASHVE TRANSACTIONS, Vol. 38, 1932, p. 463).
- ³²D. W. Nelson and D. J. Stewart: ASHVE RESEARCH REPORT No. 1076—Air distribution from side wall outlets (ASHVE TRANSACTIONS, Vol. 44, 1938, p. 77).
- ³³G. L. Tuve: Measuring air flow (Heating, Piping and Air Conditioning, December 1941).
- ³⁴G. L. Tuve, D. K. Wright, Jr., and L. J. Siegel: ASHVE RESEARCH REPORT No. 1140—The use of air velocity meters (ASHVE TRANSACTIONS, Vol. 45, 1939, p. 645).
- ³⁵O. W. Arnsperg and Margaret Ingels: Temperature, humidity and air motion effects in ventilation (ASHVE TRANSACTIONS, Vol. 28, 1922, p. 103).
- ³⁶H. B. Nottage, J. G. Slaby, and W. P. Gojzsa: A smoke-filament technique for experimental research in room air distribution (ASHVE TRANSACTIONS, Vol. 58, 1952, p. 399).
- ³⁷J. B. Dick: Measurement of ventilation using tracer gas technique (ASHVE JOURNAL SECTION, Heating, Piping and Air Conditioning, May 1950, p. 131).
- ³⁸C. W. Coblenz and P. R. Achenbach: ASHAE RESEARCH REPORT No. 1616—Design and performance of a portable infiltration meter (ASHAE TRANSACTIONS, Vol. 63, 1957, p. 477).
- ³⁹W. H. Carrier: The temperature of evaporation (ASHVE TRANSACTIONS, Vol. 24, 1918, p. 25).
- ⁴⁰H. B. Nottage: ASHVE RESEARCH REPORT No. 1401—A proposed psychrometric chart (ASHVE TRANSACTIONS, Vol. 56, 1950, p. 411).
- ⁴¹W. H. Carrier and C. O. Mackey: A review of existing psychrometric data in relation to practical engineering problems (ASME TRANSACTIONS, January 1937, p. 33). Discussion (ASME TRANSACTIONS, August 1937, p. 528).
- ⁴²Arnold Wexler: *Divided Flow Low Temperature Humidity Test Apparatus* (National Bureau of Standards Research Paper No. 1894).
- ⁴³H. A. Daynes: *Gas Analysis by Measurement of Thermal Conductivity* (Cambridge Press, New York, 1953).
- ⁴⁴H. M. Vernon: The measurement, in relation to human comfort, of the radiation produced by various heating systems

(Institution Heating Ventilating Engineers Proceedings, Vol. 31, p. 180).

⁴⁵T. Bedford and C. G. Warner: The globe thermometer in studies of heating and ventilating (Institution Heating Ventilating Engineers Journal, Vol. 2, 1935, p. 544).

⁴⁶D. J. Sutton and P. E. McNall, Jr.: A two-sphere radiometer (ASHVE TRANSACTIONS, Vol. 60, 1954, p. 297).

⁴⁷A. C. Willard, A. P. Kratz, and M. K. Fahnestock: The application of the eupatheoscope for measuring the performance of direct radiation and convection in terms of equivalent temperature (ASHVE TRANSACTIONS, Vol. 39, 1933, p. 303).

⁴⁸C. P. Yaglou: Physical procedures in air analysis—Instruments and methods for recording thermal factors affecting human comfort (American Journal Public Health Supplement, Vol. 26, March 1936, p. 76). C. P. Yaglou, A. P. Kratz, and C. E. A. Winslow: Instruments and methods for recording thermal factors affecting human comfort, I—Report of subcommittee on physical procedures in air analysis (American Journal Public Health Supplement, Vol. 27, March 1937, p. 84).

⁴⁹C. E. A. Winslow and Leonard Greenburg: The thermo-integrator—a new instrument for the observation of thermal interchanges (ASHVE TRANSACTIONS, Vol. 41, 1935, p. 149).

⁵⁰Standard Method of Test for Thermal Conductivity of Materials by Means of the Guarded Hot Plate (adopted July 1942 by ASHVE, ASTM Designation C 177-45).

⁵¹Tentative Method of Test for Thermal Conductivity of Pipe Insulation (ASTM Designation C 335-54T).

⁵²D. D'Eustachio and R. E. Schreiner: A study of transient heat method for measuring thermal conductivity (ASHVE TRANSACTIONS, Vol. 58, 1952, p. 331).

⁵³F. C. Hooper and F. R. Lepper: Transient heat flow apparatus for the determination of thermal conductivity (ASHVE TRANSACTIONS, Vol. 56, 1950, p. 309).

⁵⁴F. C. Hooper and S. C. Chang: Development of thermal conductivity probe (ASHVE TRANSACTIONS, Vol. 59, 1953, p. 463).

⁵⁵C. P. Lents: A transient heat flow method of determining thermal conductivity: Application to insulating materials (Canadian Journal of Technology, Vol. 30, June 1952, p. 153).

⁵⁶Tentative Method of Test for Thermal Conductance and Transmittance of Built-up Sections by Means of Guarded Hot Box (American Society for Testing Materials, ASTM-C-236-49T).

⁵⁷P. Nicholls: ASHVE RESEARCH REPORT No. 685—Measuring heat transmission in building structures and a heat transmission meter (ASHVE TRANSACTIONS, Vol. 30, 1924, p. 65).

⁵⁸R. G. Huebner, L. F. Schutrum, and G. V. Parmelee: A low-inertia low-resistance heat flow meter (ASHVE TRANSACTIONS, Vol. 58, 1952, p. 275).

⁵⁹J. T. Gier and R. V. Dunkle: Using the heat flow meter to study heat transfer (Refrigerating Engineering, Vol. 62, October 1954, p. 63).

⁶⁰I = B = R Testing and Rating Codes for Low Pressure Heating Boilers (Institute of Boiler and Radiator Manufacturers, 1947).

⁶¹Commercial Standard for Warm Air Furnaces Equipped with Vaporizing Pot-type Oil Burners (National Bureau of Standards, CS. 104-26).

⁶²Martin Shepherd: Rapid determination of small amounts of carbon monoxide (Industrial and Engineering Chemistry, Analytical Edition, 19, 7, 1947).

⁶³Martin Shepherd: Determination of small amounts of carbon monoxide in air by various reference methods (National Bureau of Standards Journal of Research 38, 351, 1947, R. P. 1777).

⁶⁴Commercial Standard for Mechanical Draft Oil Burners Designed for Domestic Installations (National Bureau of Standards, CS. 75-42).

⁶⁵Philip Drinker and Theodore Hatch: *Industrial Dusts* (McGraw-Hill Book Co., New York).