




ARMCO INC.

801 Young Street
Middletown, OH 45043



TELECOPY COVER PAGE

TO: JOHN HERDT

TELECOPY NO. (713)-455-0361 #4

FROM: KAREL JELINEK

TELEPHONE NO. (513)-425-5717

DATE: Thu, Sep 27, 1990

Number of pages transmitted including this page: 2

COMMENTS:

JOHN, ATTACHED ARE RESULTS ON ASBESTOS SAMPLES. KAREL

**TELECOPIES ARE RECEIVED
AT THIS OFFICE AT (513)-425-2537**

ARM 243

ARM000117

GREENS PORT INDUSTRIAL PARK
INSULATION SAMPLES

Collected September 19, 1990 by JRH

Sample Number	Location	Result
1	10" Line North of BCM Plant	Glass Fibers No Asbestos
2	10" Line North of DR Plant INSIDE CONCRETE TO SIDE OF TOWER TO BE REMOVED	Amosite Asbestos
3	2" Line North of BCM Plant	No Asbestos
4	North Side DR Plan (JOB)	Glass Fibers No Asbestos
5	Pile Under Hi Line (JOB) A	Glass & Synthetic Fibers-No Asbestos
6	Pile Under Hi Line (JOB) B	Amosite Asbestos
7	Pile Under Hi Line (JOB) C	Cellulose Glass Fibers-No Asbestos
8	North Side of BF Plant	Glass Fibers No Asbestos

Daybook 6460, p. 98
by: Jim Phillabaum - RC
9/21/90

KJ15

ARM 244

ARM000118