

TABLE 2. THERMODYNAMIC PROPERTIES OF MOIST AIR* (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. Hg) (Continued)

FAHR. TEMP. t(F)	HUMIDITY RATIO W _a	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. t(F)
		v _a	v _{as}	v _s	h _a	h _{as}	h _s	s _a	s _{as}	s _s	Enthalpy Btu/Lb h _w	Entropy Btu/(Lb) (°F) s _w	Vap. Press In. Hg p _s	
140	0.1534	15.117	3.702	18.819	33.655	172.0	205.7	0.06390	0.3047	0.3686	107.99	0.1985	5.8838	140
141	0.1584	15.142	3.829	18.971	33.896	177.7	211.6	0.06430	0.3142	0.3785	108.99	0.2002	6.0367	141
142	0.1636	15.167	3.961	19.128	34.136	183.6	217.7	0.06470	0.3241	0.3888	109.99	0.2018	6.1930	142
143	0.1689	15.192	4.098	19.290	34.377	189.7	224.1	0.06510	0.3343	0.3994	110.99	0.2035	6.3527	143
144	0.1745	15.218	4.239	19.457	34.618	196.0	230.6	0.06549	0.3449	0.4104	111.99	0.2051	6.5160	144
145	0.1803	15.243	4.386	19.629	34.859	202.5	237.4	0.06589	0.3559	0.4218	112.99	0.2068	6.6828	145
146	0.1862	15.268	4.539	19.807	35.099	209.3	244.4	0.06629	0.3672	0.4335	113.99	0.2084	6.8532	146
147	0.1924	15.293	4.698	19.991	35.340	216.4	251.7	0.06669	0.3790	0.4457	114.99	0.2101	7.0273	147
148	0.1989	15.319	4.862	20.181	35.581	223.7	259.3	0.06708	0.3912	0.4583	115.99	0.2117	7.2051	148
149	0.2055	15.344	5.033	20.377	35.822	231.3	267.1	0.06748	0.4038	0.4713	116.99	0.2134	7.3867	149
150	0.2125	15.369	5.211	20.580	36.063	239.2	275.3	0.06787	0.4169	0.4848	117.99	0.2150	7.5722	150
151	0.2197	15.394	5.396	20.790	36.304	247.3	283.6	0.06827	0.4304	0.4987	118.99	0.2167	7.7616	151
152	0.2271	15.420	5.587	21.007	36.545	255.9	292.4	0.06866	0.4445	0.5132	119.99	0.2183	7.9550	152
153	0.2349	15.445	5.788	21.233	36.785	264.7	301.5	0.06906	0.4591	0.5282	120.99	0.2200	8.1525	153
154	0.2430	15.470	5.996	21.466	37.026	273.9	310.9	0.06945	0.4743	0.5438	121.99	0.2216	8.3541	154
155	0.2514	15.496	6.213	21.709	37.267	283.5	320.8	0.06984	0.4901	0.5599	122.99	0.2232	8.5599	155
156	0.2602	15.521	6.439	21.960	37.508	293.5	331.0	0.07023	0.5066	0.5768	123.99	0.2248	8.7701	156
157	0.2693	15.546	6.675	22.221	37.749	303.9	341.7	0.07062	0.5237	0.5943	124.99	0.2265	8.9846	157
158	0.2788	15.571	6.922	22.493	37.990	314.7	352.7	0.07101	0.5415	0.6125	125.99	0.2281	9.2036	158
159	0.2887	15.597	7.178	22.775	38.231	326.0	364.2	0.07140	0.5600	0.6314	127.00	0.2297	9.4271	159
160	0.2990	15.622	7.446	23.068	38.472	337.8	376.3	0.07179	0.5793	0.6511	128.00	0.2313	9.6566	160
161	0.3098	15.647	7.727	23.374	38.713	350.1	388.8	0.07218	0.5994	0.6716	129.00	0.2329	9.8976	161
162	0.3211	15.672	8.020	23.692	38.954	363.0	402.0	0.07257	0.6204	0.6930	130.00	0.2345	10.125	162
163	0.3329	15.698	8.326	24.024	39.195	376.5	415.7	0.07296	0.6423	0.7153	131.00	0.2361	10.367	163
164	0.3452	15.723	8.648	24.371	39.436	390.5	429.9	0.07334	0.6652	0.7385	132.00	0.2377	10.614	164
165	0.3581	15.748	8.985	24.733	39.677	405.3	445.0	0.07373	0.6892	0.7629	133.00	0.2393	10.868	165
166	0.3716	15.773	9.339	25.112	39.918	420.8	460.7	0.07411	0.7142	0.7883	134.00	0.2409	11.123	166
167	0.3858	15.799	9.708	25.507	40.159	437.0	477.2	0.07450	0.7405	0.8150	135.01	0.2426	11.385	167
168	0.4007	15.824	10.098	25.922	40.400	454.0	494.4	0.07488	0.7680	0.8429	136.01	0.2441	11.652	168
169	0.4163	15.849	10.508	26.357	40.641	471.8	512.4	0.07527	0.7969	0.8722	137.01	0.2457	11.925	169
170	0.4327	15.874	10.938	26.812	40.882	490.6	531.5	0.07565	0.8273	0.9030	138.01	0.2473	12.203	170
171	0.4500	15.900	11.391	27.291	41.123	510.4	551.5	0.07603	0.8592	0.9352	139.01	0.2489	12.486	171
172	0.4682	15.925	11.870	27.795	41.364	531.3	572.7	0.07641	0.8927	0.9691	140.01	0.2505	12.775	172
173	0.4875	15.950	12.376	28.326	41.605	553.3	594.9	0.07680	0.9281	1.0049	141.01	0.2521	13.069	173
174	0.5078	15.975	12.911	28.886	41.846	576.5	618.3	0.07718	0.9654	1.0426	142.02	0.2537	13.369	174

* Compiled by John A. Goff and S. Gratch.

TABLE 2. THERMODYNAMIC PROPERTIES OF MOIST AIR* (STANDARD ATMOSPHERIC PRESSURE, 29.921 IN. Hg) (Concluded)

FAHR. TEMP. t(F)	HUMIDITY RATIO W _a	VOLUME CU FT/LB DRY AIR			ENTHALPY BTU/LB DRY AIR			ENTROPY BTU PER (°F) (LB DRY AIR)			CONDENSED WATER			FAHR. TEMP. t(F)
		v _a	v _{as}	v _s	h _a	h _{as}	h _s	s _a	s _{as}	s _s	Enthalpy Btu/Lb h _w	Entropy Btu/(Lb) (°F) s _w	Vap. Press In. Hg p _s	
175	0.5292	16.001	13.475	29.476	42.087	601.1	643.2	0.07756	1.005	1.083	143.02	0.2553	13.675	175
176	0.5519	16.026	14.074	30.100	42.328	627.1	669.4	0.07794	1.047	1.125	144.02	0.2568	13.987	176
177	0.5760	16.051	14.710	30.781	42.569	654.7	697.3	0.07832	1.091	1.169	145.02	0.2584	14.304	177
178	0.6016	16.076	15.386	31.462	42.810	684.1	726.9	0.07870	1.137	1.218	146.03	0.2600	14.628	178
179	0.6288	16.102	16.104	32.206	43.051	715.2	758.3	0.07908	1.187	1.266	147.03	0.2616	14.958	179
180	0.6578	16.127	16.870	32.997	43.292	748.5	791.8	0.07946	1.240	1.319	148.03	0.2631	15.294	180
181	0.6887	16.152	17.689	33.841	43.534	783.9	827.4	0.07984	1.296	1.376	149.03	0.2647	15.636	181
182	0.7218	16.177	18.565	34.742	43.775	821.9	865.7	0.08021	1.357	1.437	150.04	0.2662	15.985	182
183	0.7572	16.203	19.504	35.707	44.016	862.5	906.5	0.08059	1.421	1.502	151.04	0.2678	16.340	183
184	0.7953	16.228	20.513	36.741	44.257	906.2	950.5	0.08096	1.490	1.571	152.04	0.2693	16.702	184
185	0.8363	16.253	21.601	37.854	44.498	953.2	997.7	0.08134	1.565	1.646	153.05	0.2709	17.071	185
186	0.8805	16.278	22.775	39.053	44.740	1004	1049	0.08171	1.645	1.727	154.05	0.2724	17.446	186
187	0.9283	16.304	24.047	40.351	44.981	1059	1104	0.08208	1.731	1.813	155.05	0.2740	17.828	187
188	0.9802	16.329	25.427	41.766	45.222	1119	1164	0.08245	1.825	1.907	156.06	0.2755	18.217	188
189	1.037	16.354	26.934	43.288	45.463	1184	1229	0.08283	1.928	2.011	157.06	0.2771	18.614	189
190	1.099	16.379	28.580	44.959	45.704	1255	1301	0.08320	2.039	2.122	158.07	0.2786	19.017	190
191	1.166	16.405	30.385	46.790	45.946	1332	1378	0.08357	2.161	2.245	159.07	0.2802	19.427	191
192	1.241	16.430	32.376	48.805	46.187	1418	1464	0.08394	2.296	2.380	160.07	0.2817	19.845	192
193	1.324	16.455	34.581	51.036	46.428	1513	1559	0.08431	2.444	2.528	161.08	0.2833	20.271	193
194	1.416	16.480	37.036	53.516	46.670	1619	1666	0.08468	2.609	2.694	162.08	0.2848	20.704	194
195	1.519	16.506	39.785	56.291	46.911	1737	1784	0.08505	2.794	2.879	163.09	0.2864	21.145	195
196	1.635	16.531	42.885	59.416	47.153	1871	1913	0.08542	3.002	3.087	164.09	0.2879	21.594	196
197	1.767	16.556	46.402	62.958	47.394	2022	2069	0.08579	3.238	3.324	165.10	0.2895	22.050	197
198	1.917	16.581	50.426	67.007	47.636	2195	2243	0.08616	3.507	3.593	166.10	0.2910	22.514	198
199	2.091	16.607	55.074	71.681	47.877	2395	2443	0.08653	3.817	3.904	167.11	0.2925	22.987	199
200	2.295	16.632	60.510	77.142	48.119	2629	2677	0.08689	4.179	4.266	168.11	0.2940	23.468	200

* Compiled by John A. Goff and S. Gratch.