DICTATE IN SEQUENCE:
1. HEADING INFORMATION
2. NAMES OF ADDRESSEES
3. NAMES OF CARBONEES
4. IMMEDIATE ACTION NEEDED
5. REPORT ON CALL

REPORT CAPTIONS:
1. OBJECTIVE
2. PERSONS CONTACTED
3. RESULTS
4. ACTION REQUIRED

CUSTOMER NAME		DATE OF CALL
CITY AND STATE	DATE RECEIVED	DATE TYPED

CUSTOMER MAILING LIST CHANGES – SERVICE CENTER USE ONLY

NAME AND TITLE	PUT ON	TAKE OFF	MP	MAG.	CATEGORY CODES

REGION	SERVICE CENTER	SALESMAN
	Houston	Hoover

① DAO
② DER 5711 + file to check out a design
Apparently Jim asked Roger to check out a design

TO JIM RODEE CC J. R. FALLON PAGE 1.

WENT THRU SOME FAST NUMBERS AND SYSTEM LOOKS LIKE —

USING EXIST. 185 GPM PUMP AT 120 FT HEAD
HEATER TUBE VELOCITY 8.7 FT/SEC ±
EST. MAX FILM RISE 47°F
* EST PRESSURE DROP THRU HEATER 33 ~~30~~ FT

Check schematic
Need Head Loss

USING NEW PUMP at 200 G.P.M
TUBE VEL. 5 FT/Sec ±
EST MAX FILM RISE 40°F
* EST PRESSURE DROP THRU HEATER 12 FT
* BECAUSE OF LACK OF DATA - ΔP IS BASED ON DOWA —

SEE SKETCH FOR TYPICAL PIPING —

MOVE CONTROL VALVES TO BOTTOM SIDE TO AVOID ANY POSS. CHANCE OF FLASHING at THE ABOVE TEMPERATURES.

PIPE HIGH TEMP. SUPPLY INTO BOTTOM OF JACKET - USE MINIMUM ~~MAXIMUM~~ OF 4 OUTLETS AROUND TOP EDGE - WITH PRESSURE GAUGE AND HAND VALVE TO BALANCE OUT FLOW - (MAYBE)

IF WE HAD THE PHYSICAL DATA - PIPE SIZES - KETTLE DIMS ETC MIGHT BE ABLE TO EST. HEAT TRANSFER COEF —

(Jim)

S-331 (REV. 12/66)

1 – CENTRAL OFFICE COPY

DSW 435003

STLCOPCB4088063

TYPING SEQUENCE:
1. HEADING INFORMATION
2. NAMES OF ADDRESSEES
3. NAMES OF CARBONEES
4. IMMEDIATE ACTION NEEDED
5. REPORT ON CALL

REPORT CAPTIONS:
1. OBJECTIVE
2. PERSONS CONTACTED
3. RESULTS
4. ACTION REQUIRED

CUSTOMER NAME		DATE OF CALL
GRAIN MILLS		11-5-69
CITY AND STATE	DATE RECEIVED	DATE TYPED

CUSTOMER MAILING LIST CHANGES – SERVICE CENTER USE ONLY

NAME AND TITLE	PUT ON	TAKE OFF	MP	MAG.	CATEGORY CODES

REGION	SERVICE CENTER	SALESMAN

TO CC

PAGE 2

YOU HAD BETTER CHECK OUT THE CONDENSATE PUMPS - THEY ARE PROBABLE TO SMALL IF SIZED FOR VAPOR - ASSUMING 500,000 BTU/HR PER USER (4) THE PUMP WOULD ONLY HAVE TO MOVE 70 GPH AT 115 BTU/# LATENT HEAT -


IF THIS DOESNT WORK - HELL - SELL EM AN ECLIPSE HEATER NEW -

DSW 435004

S-331 (REV. 12/68)

1 – CENTRAL OFFICE COPY

STLCOPCB4088064



MULTIPLE TEMPERATURE ZONES WITH SINGLE THERMINOL HEATER

DSW 435005

STLCOPCB4088065