



Startup Requirements

- MATS had two options for defining startup:
 - Definition #1: startup ends when steam is used for generation or any on-site purpose
 - requires use of clean fuels for ignition and control device use when coal/oil combustion begins (except for dry scrubber or selective catalytic reduction units, which come online as conditions allow)
 - Definition #2: startup ends 4 hours after the start of generation of electricity or useful thermal energy
 - operators must provide records of clean and non-clean fuel use, load characteristics, as well as exhaust flow and PM control device parameters
- **Final Rule: Removes startup definition #2**