

DATE : February 7, 1979 cc : SHAC Members
SUBJECT : HOURLY SAFETY COMMITTEE MEETING
TUESDAY, JANUARY 30, 1979
REFERENCE :
TO : File

PLAINTIFF'S EXHIBIT

MON-623

Present

Jim Froeble
Don Barnhill
Gerry Berry
John Clemmon
Jake Linkey
Joe Lowe
Herbie Townsend

Absent

Hugh Bowen
Dudley Packard

A. General

1. J. A. Glass explained the safety organization to the new Hourly Safety Committee.
2. Fire/Entry and Lockout Procedures were discussed.
3. Question was asked if past practice for old Hourly Safety Committee having a dinner still holds?

B. Old Business: (which needs reply)

1. Ability to hear fire alarms and "all clear" still a problem around the plant--especially at Dock 4 & 5 and Department 42. 332 STE { 15-14 Control room
2. Insulation Banding--Needa means to cover or do away with exposed razor edges. (Aw Kuchl, to remove)

3) only exception is AV-5
6)

SC 17145

LAM025397

C. New Business

- Sprinkler
valves*
1. Some fire monitor valves were found carsealed closed in the East Plant. Additionally, the valves were hard to operate. What is Standard practice? *Get hard to open* J A Guss to review (< 518)
 2. A concern was expressed that the HCN alarm in Dept. 19/25/27/29 and HCN Storage Tanks can't be heard in the AN Loading Shack. *A.H. Conrad to review*
 3. There are some valves inside the 14th diked area that require walking through some liquid. It was feared that this liquid contained SM and TBC. *(RA Hernandez to review)*

Tom Kemisk. 2390

*Rob 2311
Platform*

Raul

R. A. Hernandez

tg

SC 17146

LAM025398