

SPECIFICATION INFORMATION CHANGE
Western Electric Company, Incorporated
Purchased Products Engineering

S.I.C. 1.4019
Issue 1

AT-8832, ISSUE 2
B CAULKING COMPOUND
(Fire-Rated)
(Special Practice)
(Uniseal, Inc.)

1. REQUIREMENTS

1.1 The following changes have been authorized.

1.11 Paragraph 6.03 - In addition to the one and five pound sizes, an extruded strip form (1" x 3/8" x 8') shall be available. The strip from shall be unit packed on a roll. Each roll shall be wound around a core; the convoluted strip shall be separated by strips of silicone coated glassine type release paper. The release paper shall have the same width as the core.

2. AUTHORIZATION

2.1 Meeting held at PPE on October 7, 1980.

3. REFERENCE

3.1 File: 2000 Engineering

4. CHANGE CLASSIFICATION

4.1 The changes authorized herein shall be put into effect by the manufacturer as soon as practicable.

5. SAMPLES

5.1 Two production samples indicating conformance to the changes above shall be required from the contract supplier.

APPROVED:

JAN 05 1981

JAG:MS - 62SZ02462

E. P. HJORTH
Department Chief
Purchased Products
Engineering