



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION VI
ALLIED BANK TOWER AT FOUNTAIN PLACE
1445 ROSS AVENUE
DALLAS, TEXAS 75202

May 18, 1987

REPLY TO: 6W-EAO

Mr. T. G. Brown
Works Manager
PPG Industries, Inc.
P. O. Box 1000
Lake Charles, Louisiana 70602

Re: NPDES Permit No. LA0000761

Dear Mr. Brown:

We note that your facility is in violation of the above referenced permit, specifically, the following violations:

<u>Date</u>	<u>Outfall</u>	<u>Parameter</u>	<u>Violation</u>	<u>Permit Limit</u>
✓ February 10, 1987	001	pH, max.	9.3 s.u.	9.0 s.u.
✓ February 22, 1987	001	pH, max.	9.4 s.u.	9.0 s.u.
✓ February 27, 1987	001	pH, max.	9.8 s.u.	9.0 s.u.
✓ March 9, 1987	001	pH, max.	*	9.0 s.u.
✓ March 18, 1987	001	pH, max.	*	9.0 s.u.
✓ March 18, 1987	004	pH, max.	*	9.0 s.u.
✓ March 25, 1987	004	pH, max.	*	9.0 s.u.

→ *Reported maximum values on Discharge Monitoring Report (DMR) do not agree with NCR letter submitted with DMR. Please provide explanation of differences.

Your facility should take whatever remedial action is necessary to prevent the recurrence of the violations noted above.

A report of the above violations will be placed in your file. The report will be used in our consideration of the appropriate action to be taken in the event of future violations of the permit.

SL 026641

If you have any questions on this matter, please contact me at the above address or telephone (214) 655-9065.

Sincerely,

A handwritten signature in cursive script that reads "Thomas Lewerenz".

Thomas Lewerenz
Enforcement Branch, 6W-EAO

cc: Mr. Marion Fannaly
Enforcement Coordinator
Louisiana Dept. of Environmental Quality
P.O. Box 44066, Capitol Station
Baton Rouge, Louisiana 70804-406

SL 026642