

P.1431

GRACE

Construction Products Division

W. R. Grace & Co.
62 Whittemore Avenue
Cambridge, Mass. 02140

(617) 876-1400

May 19, 1983

Dr. R. W. McKinney
Washington Research Center
W. R. Grace & Co.
7379 Route 32
Columbia, MD 21046

Dear Bob,

The air samples which M. Smith submitted were evaluated, and the results are attached herewith.

The fiber counts are very low. The 8-hour TWA is less than 0.05 fiber/ml, far below the OSHA allowed limit (for chrysotile 8-hour TWA is 2 f/ml).

However, if the insulation is loose, it is advisable to secure it some way, since it contains chrysotile asbestos.

If you have any questions, please let me know.

Sincerely yours,

Julie
Julie C. Yang

JCY/pm
Enclosure

cc: M. Smith/WRC



Car Ex 1
2829