

JOHN A. LOVE
Governor

JAMES M. SHAFFER
Executive Director



DEPARTMENT OF LABOR AND EMPLOYMENT

DIVISION OF LABOR, SAFETY SECTION

200 EAST NINTH AVENUE
DENVER, COLORADO 80203

JAMES A. UNDERWOOD
Supervisor

June 23, 1971

PLAINTIFF'S EXHIBIT

BAB-392

Mr. Alvin Henry Haberland
Administrative Assistant
Public Service Company of Colorado
550 15th Street
Denver, Colorado 80202


Dear Hank,

As you may know, there is almost always a reason, sometimes not good, for my failure to do something. In the case of writing the letter to you regarding the low water fuel cut off requirements in the new Boiler Law, I have been waiting to find out if it would in deed become law. Governor Love finally signed the Law and we have now completed mimeographing it for general consumption. I enclose a copy.

As I have said to you, it was not the intent when compiling this new law, to cause the Public Service Company or any other utility to make any alterations in the pressure control systems.

Please consider this as the official statement of the Boiler Inspection Branch that under the provisions of the law which take into account the constant presence of specially trained operating personnel, it will not be necessary to install any additional fuel regulating controls.

Yours very truly,


Jacob K. Mahr
Chief Boiler Inspector

JHM:dsm

Enclosure

WAD00228

Chas. Speer

Chas. Speer

Top sheet is inter sheet
for 1970-75.

Application form to be
made out in duplicate

1 copy to Hartford

1 - State of Cal.

Deputy Labor & Emp.

John M. Mahr

Suggest you start now
with your application to
omit internal inspection
of #1 bld in 1970.

Please review your copy of
the agreement. *Chas*

Hartford Steam Boiler Inspection & Insurance Co.
816 Insurance Exchange Building
Denver, Colorado 80202

ATTENTION: Mr. George F. Ward

Gentlemen:

SUBJECT: BOILER INSPECTION FREQUENCY
OUR AGREEMENT OF OCTOBER 9, 1969

In accordance with the agreement between State of Colorado, Department of Labor and Employment, the Hartford Steam Boiler Inspection & Insurance Co. and the Public Service Company of Colorado, dated October 9, 1969, we submit this application for extension of interval between internal boiler inspections of the below described steam generator to thirty months:

Boiler Number _____ Serial Number _____

Location _____

Address _____

Description _____

#/Hr. _____ Psig _____

Total Temperature _____ °F

Date of Last Inspection _____

Name of Inspector _____

Your consideration of the above application will be appreciated.

Sincerely yours,

WAD00230