

SHUTTING DOWN A WTU STEAM STRIPPER

CHECK	ACTION STEPS (all caps) COMMENTS (below steps)
_____	1. FOLLOW PROCEDURE FOR PUTTING A STRIPPER ON RECYCLE.
_____	2. SHUTDOWN STEAM STRIPPER FEED PUMPS. CLOSE DISCHARGE BLOCK VALVES.
_____	3. SHUTDOWN STRIPPER BOTTOMS PUMPS AND CLOSE DISCHARGE BLOCK VALVES.
_____	4. PUMP DOWN PHASE SEPARATOR. SHUTDOWN PRODUCT PUMPS AND CLOSE THE DISCHARGE VALVES IF BOTH UNITS ARE SHUTTING DOWN.
_____	5. DRAIN SYSTEM.
_____	6. BLOCK STEAM AND DRAIN LIVE STEAM AND CONDENSATE AT THE STEAM STRIPPER STEAM STATIONS.

CONFIDENTIAL:
Subject to Protective Order
of 14th Judicial District Court
No. 91-1145