HEAT EQUIVALENT OF AIR INFILTRATION

The heat required to warm cold outside air, which enters a room by infiltration, to the temperature of the room is given by the following equation:

$$H_1 = 0.24\ Q\ d\ (t - t_o) \qquad (3)$$

where

H_1 = Btu per hour required for heating air leaking into building from outside temperature t_o to inside temperature t.

Q = cubic feet of air entering per hour at inside temperature t.

d = density (pounds per cubic foot) of air at inside temperature t.

t = inside temperature at the proper level.

t_o = outside air temperature for which heating system is designed.

0.24 = specific heat of air.

It is sufficiently accurate to take $d = 0.075$ lb, in which case the equation reduces to

$$H_1 = 0.018\ Q\ (t - t_o) \qquad (4)$$

While a heating reserve must be provided to warm inleaking air on the windward side of a building, this does not necessarily mean that the heating plant must be provided with a reserve capacity, since the inleaking air, warmed at once by adequate heating surface in exposed rooms, will move transversely and upwardly through the building, thus relieving other radiators of a part of their load. The actual loss of heat of a building caused by infiltration is not to be confused with the necessity for providing additional heating capacity for a given space. Infiltration is a disturbing factor in the heating of a building, and its maximum effect (maximum in the sense of an average of wind velocity peaks during the heating season above some reasonably chosen minimum) must be met by a properly distributed reserve of heating capacity, which reserve, however, is not in use at all places at the same time, nor in any one place at all times.

REFERENCES

Air Leakage, by F. C. Houghten and C. C. Schrader (A.S.H.V.E. Transactions, Vol. 30, 1924).

Air Leakage around Window Openings, by C. C. Schrader (A.S.H.V.E. Transactions, Vol. 30, 1924).

Neutral Zone in Ventilating, by J. E. Emswiler (A.S.H.V.E. Transactions, Vol. 32, 1926).

Infiltration through Plastered and Unplastered Brick Walls, by F. C. Houghten and Margaret Ingels (A.S.H.V.E. Transactions, Vol. 33, 1927).

Effect of Frame Calking and Storm Sash on Infiltration around and through Windows, by W. M. Richtmann and C. Braatz (A.S.H.V.E. Transactions, Vol. 34, 1928).

Air Leakage on Metal Windows in a Modern Office Building, by F. C. Houghten and M. E. O'Connell (A.S.H.V.E. Transactions, Vol. 34, 1928).

The Weathertightness of Rolled Section Steel Windows, by J. E. Emswiler and W. C. Randall (A.S.H.V.E. Transactions, Vol. 34, 1928).

Air Leakage through a Pivoted Metal Window, by F. C. Houghten and M. E. O'Connell (A.S.H.V.E. Transactions, Vol. 34, 1928).

Air Infiltration through Various Types of Brick Wall Construction, by G. L. Larson, D. W. Nelson and C. Braatz (A.S.H.V.E. Transactions, Vol. 35, 1929).

Pressure Difference across Windows in Relation to Wind Velocity, by J. E. Emswiler and W. C. Randall (A.S.H.V.E. Transactions, Vol. 36, 1930).

Air Infiltration Through Various Types of Wood Frame Construction, by G. L. Larson, D. W. Nelson and C. Braatz (A.S.H.V.E. Transactions, Vol. 36, 1930).

Air Infiltration Through Double-Hung Wood Windows, by G. L. Larson, D. W. Nelson and R. W. Kubasta (A.S.H.V.E. Transactions, Vol. 37, 1931).

Flue Action in Tall Buildings, by H. L. Alt (*Heating, Piping and Air Conditioning*, May, 1932).

Air Infiltration Through Steel Framed Windows, by D. O. Rusk, V. H. Cherry and L. Boelter (*Heating, Piping and Air Conditioning*, October, 1932).

Investigation of Air Outlets in Class Room Ventilation, by G. L. Larson, D. W. Nelson, and R. W. Kubasta (A.S.H.V.E. Transactions, Vol. 38, 1932).

Influence of Stack Effect on the Heat Loss in Tall Buildings, by Axel Marin (A.S.H.V.E. Transactions, Vol. 40, 1934).

Wind Velocities Near a Building and Their Effect on Heat Loss, by F. C. Houghten, J. L. Blackshaw, and Carl Gutberlet (A.S.H.V.E. Transactions, Vol. 40, 1934).

Fuel Saving Resulting from the Use of Storm Windows and Doors, by A. P. Kratz and S. Konzo (A.S.H.V.E. Journal Section, *Heating, Piping and Air Conditioning*, December, 1935).

The Infiltration Problem of Multiple Entrances, by A. M. Simpson and K. B. Atkinson (A.S.H.V.E. Journal Section, *Heating, Piping and Air Conditioning*, June, 1936).

Infiltration Characteristics of Entrance Doors, by A. M. Simpson (*Refrigerating Engineering*, June, 1936).

PROBLEMS IN PRACTICE

1 ● Why is it important in exterior walls of air space construction to place a wind stop in the outer surface?

During the heating season, air within the space is at a higher temperature than outdoor air. If cracks are present in the outer surface, a chimney action takes place which causes a continuous change of air in the space. This causes a greater heat loss through the inner wall surface for two reasons: (1) the temperature difference becomes greater and (2) the surface coefficient on the air space side is increased because of the higher air velocity. Another undesirable condition resulting from this leakage is a lowered temperature of the inside surface. The increased radiation from occupants to walls caused by this condition must be offset by higher air temperatures.

The wind stop in the outer wall surface is therefore important because:

a. It reduces the loss of heat through the wall.

b. It helps to maintain a high inner wall surface temperature.

2 ● Why is it essential to consider this in heating calculations?

The inflowing air displaces inside heated air and must be heated up to the internal temperature.

3 ● Where is it necessary to consider infiltration created by temperature difference?

In tall, single-story buildings and in multi-story buildings where the floors are not adequately isolated.

4 ● Why is the infiltration in a building less than that determined in laboratory tests?

In laboratory tests, the indicated wind velocity is measured by the difference in pressure on the two sides of a single wall, window, or object tested. In a building, an internal back pressure is built up between its walls to a point where outflow on the lee side is equal to inflow on the windward side and this back pressure reduces the actual inflow below that determined in the laboratory for a comparable wind.