

ELECTRICAL SAFETY AND RELIABILITY AUDIT CHECK LIST
FOR
MOTOR CONTROL CENTERS (MCC'S)

MCC LOCATION I.D. #:
MCC EQUIPMENT I.D. #:

T F

MCC C

MCC's

Yes No N/A

- | | | | |
|---|-------------------------------------|--------------------------|--------------------------|
| 1. Is the MCC equipped with a main disconnect? | ☒ | ☐ | ☐ |
| 2. Is the MCC equipped with molded case circuit breakers? | ☒ | ☐ | ☐ |
| 3. Is the working space clear in front of all MCC's? | ☒ | ☐ | ☐ |
| 4. Are all MCC's properly grounded? | ☒ | ☐ | ☐ |
| 5. Are all holes in doors or panels in MCC's covered with approved coverings that would withstand fault pressures and temperatures? | ☒ | ☐ | ☐ |
| 6. Are all required bolts or fasteners on cubicle doors? | ☒ | ☐ | ☐ |
| 7. Is the MCC free of corrosion? | ☒ | ☐ | ☐ |
| 8. Is the equipment designed to prevent exposure to energized bus when doors are open or closed? | ☒ | ☐ | ☐ |
| 9. Are tall indicating lamps functional? | ☒ | ☐ | ☐ |
| 10. Is the manufacturer nameplate in place and legible? | ☒ | ☐ | ☐ |
| 11. Does the MCC have provisions to lock-out the equipment? | ☒ | ☐ | ☐ |
| 12. Is the MCC on a PPM Program? | ☒ | ☐ | ☐ |
| 13. Are the fuse sizes and relay settings according to standards? | ☒ | ☐ | ☐ |
| 14. Does the working clearance in front of all MCC's meet local code requirements? | ☒ | ☐ | ☐ |

DO A 045134
CONFIDENTIAL

THE DOW CHEMICAL COMPANY
ELECTRICAL TECHNOLOGY
GLOBAL

ADMINISTRATIVE GUIDELINE
G7A-0099-04
14-JUN-1996
PAGE 2 OF 2

	Yes	No	N/A
15. Is control voltage 120 volt?	☒	☐	☐
16. Is bus system insulated or covered?	☒	☐	☐

MCC's Index Score: 3

DO A 045135
CONFIDENTIAL