

SUBJECT: MODIFICATIONS TO UNDERGROUND PIPING SPECIFICATIONS

DATE AND REVISION: 9/7/90, Rev. 1

PREPARED BY: Diana Martin

<u>UCC SPEC/DATE</u>	<u>ITEM</u>	<u>CHANGES MADE TO THE CURRENT UCC SPEC.</u>	<u>REASON</u>
1X8 June 1988	1	Use ASTM A193 Bolts	Current Spec still showing ASTM A307
	2	Use 1/16" Thick Grafoil GHR Gasket	Current Spec still showing Asbestos
36W1 June 1988	1	Use ASTM A193 Bolts	Current Spec still showing ASTM A307
	2	Use 1/16" Thick Grafoil GHR Gasket	Current Spec still showing Asbestos
	3	Referenced CISP Institute Spec No. HS-74	Reference in current Spec is to HS-76
	4	Updated the names of Manufacturers	Current Spec is out of date
	5	Updated Coating Mastic	Current Mastic no longer made

PLAINTIFF'S
EXHIBIT

76052.00

UCASB00229954