

TO: #824 Plasterco, J. Crepeau
FROM: #151 Libertyville, C. D. Byers *CDB*
SUBJECT: ANALYSIS OF INSULATION, AR #1977

April 14, 1987

One insulation sample was received with no specific label for the determination of the presence of asbestos. The sample was analyzed by polarized light microscopy using dispersion staining. The sample was found to contain asbestos.

CDB/tds

cc:

#143, M. F. O. 1001
#176-5, F. P. May
#151, B. W. Ost

CS012 2456