

Table 1.... Data for Determining Operating Characteristics of Snow-Melting Systems^{a, 1}

City	Period of No Snowfall				Period of Snowfall ²											Maximum output Btu/(sq ft) (hr)		
	Air Temperature, F ³			Wind speed, freezing period ⁵ , mph	Hours of snowfall ²		Required output, Btu per (sq ft) (hr) ⁴											
	Over 32	Below or equal to 32	Mean during freezing period ⁵		Per cent	Hr per year	Free area ratio, A _f	0 to 49	50 to 99	100 to 149	150 to 199	200 to 249	250 to 299	300 to 349	350 to 399		400 up	
	% of winter hours with no snow at above temperatures																	
Albuquerque, N. M.	74.7	24.7	26.2	8.5	0.6	22	1	62.0	25.4	7.6	4.2	0.0	0.8	—	—	—	259	
Amarillo, Tex.	73.1	26.0	24.6	13.3	0.9	33	1	32.7	35.9	—	—	—	—	—	—	—	82	
Boston, Mass.	64.6	31.4	24.7	14.2	4.0	145	1	88.1	10.1	1.8	—	—	—	—	—	—	143	
Buffalo	46.5	46.9	23.9	10.8	6.6	240	1	51.5	30.0	12.3	4.3	1.2	0.6	0.1	—	—	320	
Niagara Falls, N. Y.							1	88.2	14.0	2.0	0.3	0.1	—	—	—	—	—	0.2
Burlington, Vt.	39.0	54.5	19.6	10.8	6.5	236	1	50.7	32.6	11.2	3.7	1.4	0.2	0.2	—	—	309	
Caribou	21.4	70.6	16.5	10.0	8.0	290	1	95.9	3.4	0.2	0.5	—	—	—	—	—	192	
Limestone, Me.							1	53.7	29.9	13.2	2.5	0.6	0.1	—	—	—	—	—
Cheyenne, Wyo.	46.4	49.8	21.5	15.3	3.8	138	1	91.8	7.6	0.6	—	—	—	—	—	—	142	
Chicago, Ill.	45.4	50.9	21.4	11.5	3.7	134	1	35.0	39.7	16.0	5.7	2.0	1.0	0.5	0.1	—	378	
Colorado Springs, Colo.	54.3	43.6	22.1	11.5	2.1	78	1	92.0	7.5	0.5	—	—	—	—	—	—	138	
Columbus, Ohio	59.0	38.1	24.5	10.0	2.9	105	1	16.5	26.2	19.4	13.1	8.6	4.7	4.2	4.7	2.6	499	
Detroit, Mich.	47.0	49.3	24.1	10.6	3.7	134	1	94.3	5.4	0.3	—	—	—	—	—	—	129	
Duluth, Minn.	12.6	80.5	14.5	12.0	6.9	250	1	94.3	5.4	0.3	0.1	1.4	0.6	0.2	0.1	—	363	
Falmouth, Mass.	68.5	29.5	25.5	12.8	2.0	73	1	26.8	36.3	19.0	7.5	4.4	5.5	0.5	—	—	138	
Great Falls, Mont.	49.0	46.2	16.5	14.4	4.8	174	1	98.4	1.6	—	—	—	—	—	—	—	311	
Hartford, Conn.	56.4	38.9	24.4	8.2	4.7	171	1	65.8	22.4	8.0	1.7	1.7	0.4	—	—	—	261	
Lincoln, Neb.	45.0	52.5	20.8	10.1	2.5	91	1	47.7	2.3	—	—	—	—	—	—	—	72	
Memphis, Tenn.	87.2	12.5	27.0	11.5	0.3	11	1	60.4	27.7	9.3	1.5	0.8	0.3	—	—	—	278	
Minneapolis	23.6	70.8	16.9	11.1	5.6	203	1	95.9	3.5	0.6	—	—	—	—	—	—	140	
St. Paul							1	23.7	32.9	20.6	13.7	4.3	2.5	1.7	0.6	—	—	—
Mt. Home, Idaho	56.3	42.6	24.9	9.5	1.1	40	1	94.8	4.7	0.0	0.3	0.2	—	—	—	—	206	
New York, N. Y.	55.7	42.2	24.2	11.8	2.1	76	1	50.0	33.9	14.2	1.6	0.3	—	—	—	—	204	
Ogden, Utah	50.0	45.6	24.3	9.4	4.4	160	1	91.5	7.4	1.1	—	—	—	—	—	—	144	
Oklahoma City, Okla.	79.0	19.8	24.6	15.8	1.2	44	1	26.2	27.6	16.7	16.4	7.5	4.6	0.3	0.5	0.2	451	
Philadelphia, Pa.	75.8	22.6	26.7	9.7	1.6	58	1	94.6	4.8	0.6	—	—	—	—	—	—	138	
Pittsburgh, Pa.	55.2	39.8	24.3	11.6	5.0	152	1	48.4	34.6	11.2	4.3	0.8	0.7	—	—	—	396	
Portland, Ore.	92.9	6.1	28.9	8.4	1.0	36	1	80.4	16.7	2.2	0.5	—	0.1	—	—	—	383	
Rapid City, S. D.	45.2	51.6	19.3	12.9	3.2	116	1	32.7	26.2	20.0	13.9	5.7	1.5	—	—	—	293	
Reno, Nev.	56.0	41.6	24.3	5.6	2.4	87	1	97.2	2.6	0.0	0.0	0.2	—	—	—	—	202	
							1	48.4	28.3	6.7	13.3	3.3	—	—	—	—	227	
							1	88.0	8.3	0.7	—	—	—	—	—	—	144	
							1	28.4	31.4	21.7	14.1	3.5	0.6	0.3	—	—	313	
							1	96.5	3.1	0.3	0.1	—	—	—	—	—	155	
							1	74.2	21.9	3.9	—	—	—	—	—	—	143	
							1	98.1	1.9	—	—	—	—	—	—	—	90	
							1	53.1	31.8	9.4	2.2	1.5	1.7	—	0.3	—	385	
							1	87.6	9.6	1.5	0.7	0.3	0.3	—	—	—	298	
							1	64.6	29.2	5.8	0.3	0.1	—	—	—	—	216	
							1	88.8	9.4	1.4	0.3	0.1	—	—	—	—	216*	
							1	27.8	18.7	17.0	12.6	14.3	5.9	2.7	1.0	—	394	
							1	95.7	4.3	—	—	—	—	—	—	—	81	
							1	62.3	23.6	10.4	2.3	0.9	0.5	—	—	—	296	
							1	84.3	14.0	1.1	0.2	0.4	—	—	—	—	229	
							1	53.6	30.8	8.4	4.6	1.9	0.7	—	—	—	282	
							1	93.3	5.9	0.7	0.1	—	—	—	—	—	157	
							1	78.0	16.9	5.1	—	—	—	—	—	—	125	
							1	91.5	8.5	—	—	—	—	—	—	—	97	
							1	29.7	29.0	16.0	8.4	6.3	3.6	1.9	2.0	3.1	581	
							1	97.6	2.2	0.2	—	—	—	—	—	—	102	
							1	82.6	15.4	1.8	0.2	—	—	—	—	—	152	
							1	90.2	8.0	1.6	0.2	—	—	—	—	—	154*	

Table 1.... Data for determining Operating Characteristics of Snow-Melting Systems^{a, 1} (Concluded)

City	Period of No Snowfall				Period of Snowfall ²											Maximum output, Btu/ sq ft (hr)		
	Air Temperature, F ³			Wind speed freezing period, ⁵ mph	Hours of snowfall ²		Required output, Btu per (sq ft) (hr) ⁴											
	Over 32	Below or equal to 32	Mean during freezing period ⁵		Hr. per year	Free area ratio, A _f	Frequency distribution of snowfall hours at above outputs, percent ⁶											
							0 to 49	50 to 99	100 to 149	150 to 199	200 to 249	250 to 299	300 to 349	350 to 399	400- up			
St. Louis, Mo.	68.7	30.4	25.0	11.5	0.9	33	1	42.9	31.4	16.7	7.1	1.9	—	—	—	225		
Salina, Kan.	60.0	38.5	23.3	10.9	1.5	54	1	85.2	11.6	2.6	0.6	—	—	—	—	152		
Sault Ste. Marie, Mich.	21.3	69.2	18.6	9.4	9.5	345	1	44.9	31.9	12.7	7.6	2.2	0.7	—	—	286		
Seattle } Wash. Tacoma }	88.0	10.8	28.5	5.9	1.2	44	1	93.5	6.2	0.3	—	—	—	—	—	120		
							1	45.7	32.8	14.3	5.7	1.4	0.1	—	262			
Spokane, Wash.	48.5	46.1	25.7	10.7	5.4	196	1	97.9	2.0	0.1	—	—	—	—	—	144		
Washington, D. C.	77.9	21.2	26.8	9.6	0.9	33	1	86.3	12.3	1.4	—	—	—	—	—	137		
							1	91.0	8.1	0.9	—	—	—	—	—	128		
							1	62.6	28.7	7.4	1.1	2.0	—	—	—	205		
							1	92.0	7.8	0.2	—	—	—	—	—	127		
							1	59.0	29.8	10.6	0.6	—	—	—	—	154		
							1	85.7	11.8	2.5	—	—	—	—	—	121		

^a From Air Conditioning, Heating and Ventilating, August, 1957, p. 87.¹ The period covered by this table is from No. 1 to March 31, incl. with February taken as a 28½ day month. Total hours in period = 3630. ² The percentage in Columns 2 and 3 plus the percent under hours of snowfall total 100 percent. Note that Hours of Snowfall does not include idling time, and is not actual operating time. See text. ³ Snowfalls of trace amounts are not included; hence, Hours of Snowfall includes only those hours of 0.01 inches water equivalent per hour snowfall. ⁴ Output does not include allowance for back or edge losses since these depend on slab construction. ⁵ Percentages total 100 percent of the number of hours of snowfall. ⁶ Freezing Period is that during No Snowfall when the air temperature is 32 F or below. * When heat output for A_f = 0 equals or exceeds the heat output for A_f = 1, the heat transfer q_s is from the air to the slab. This occurs when snowfall is at temperatures above 32 F.The sensible heat, q_s, to raise the temperature of the snow to 32 F is

$$q_s = 2.6s(32 - t_s) \quad (3)$$

where

s = rate of snowfall, inches of water equivalent per hour.
t_s = air temperature, Fahrenheit.The heat of fusion, q_m, to melt the snow is

$$q_m = 746s \quad (4)$$

The heat of evaporation, q_e, (mass transfer) is

$$q_e = h_e(0.0201v + 0.055)(0.185 - p_{ee}) \quad (5)$$

where

h_e = heat of evaporation at the film temperature, Btu per pound.
v = wind speed, miles per hour.
p_{ee} = vapor pressure of moist air, inches of mercury.The heat transfer, q_k, (convection and radiation) is

$$q_k = 11.4(0.0201v + 0.055)(t_f - t_s) \quad (6)$$

where

t_f = water film temperature, Fahrenheit.

In addition to determining the four heating requirements, it is necessary to make allowance for back and edge losses. These losses vary from 30 to 50 percent, depending upon the slab construction and fluid temperature.

The equation for the required fluid temperature to provide

an output q_s has been derived in Reference 2. For construction similar to Fig. 1, the equation is

$$t_m = 0.5q_s + t_f \quad (7)$$

where

t_m = mean fluid temperature (antifreeze solution), Fahrenheit.
Equation 7 will apply to 1 in. as well as ¾ in. IPS pipe—see Fig. 1.

Equations 2 to 7 permit the designer to determine the heating requirement of a snow-melting system. The solutions of these equations, however, require the simultaneous consideration of the four climatic factors: (1) wind speed, (2) air temperature, (3) relative humidity, and (4) rate of snowfall. It is not satisfactory to use annual averages or maximums for the climatic factors. If averages or maximums are used there is no assurance that they will ever occur simultaneously. It is necessary, therefore, to make a frequency analysis of the solutions to Equation 2 for all the occurrences of snowfall for a period of several years. Such an analysis for 33 cities appears in Table 1 which contains the operating information for a snow-melting system. For freezing temperatures (32 F and below) without snowfall the system may be idling which means that some heat is supplied to the slab so that there will be immediate melting when snow starts to fall. Column 4 of Table 1 gives the average temperature during freezing periods. This temperature is used in calculating the idling load. The other term needed to calculate idling load is the wind speed during the period of freezing temperatures.

The column, Hours of Snowfall, indicates the number of hours that snow is falling at rates equal to or greater than 0.01 in. of water equivalent per hour. There are snowfalls of