

Viscous filters, 845
impingement, 845
Vitiating of air, 111
Volume
control, 783
furnace, 390, 397
specific, 10

W

Wall, walls
heat flow through, 181-192, 301, 324
heat transfer coefficients, 89, 181-192
infiltration through, 240
time lag of solar radiation, 322

Warm air

gravity heating system, 10, 511
mechanical (forced) heating systems, 483
air distribution, 483
automatic control, 504, 977
ceiling panel system, 505
cooling methods, 1221
continuous circulation, 504
dampers, 485
design procedure, 487, 501
ducts, 486
fans, 430
filters, 430
furnace, 429
heavy duty, 431
selection, 504
humidification, 435
large systems, 501
perimeter system, 487-500
pressure drop, 510
registers and grilles, 484
panel heating, 505
radiators, 407

Washer, washers, 867

air, 1, 858, 867
cooling, 871
dehumidification, 871
humidification, 869

Water

analysis, 1066
atmospheric cooling equipment, 875, 877

Water (continued)

characteristics, 1066
classification, 1066
coils, 896, 1213
content of radiators, 579
control temperature service, 1215
cooled
condenser, 942
cooling tower, 877
corrosion treatment, 1081
demand, 1193, 1207-1210
faucets, 1193
fittings, loss, 1198, 1205
fixtures, 1198
fixture units, 1198
formed deposits, 1065
heater
coal-fired, 1210
solar, 1217
heating, 1210
in building material, 219
load, 1197
make-up, 891, 1075
maximum main temperature, 870
meters, 1203
mineralized, 1066
properties of, 40, 1066
services, 1197
storage capacity, 1207
supply piping, 1214
arrangement, 1214
temperature control, 1215
thermodynamic properties of, 40
treating chemicals, 1065, 1066
well temperatures, 872
Water vapor, 25, 32-39, 217
condensation in buildings, 217
saturation pressure, 25, 40
specific enthalpy, 4
specific volume, 10, 40
surface condensation, 229
Weather conditions
design outdoor, 262, 289

Welding, 692

Wet-bulb temperature (see temperature), 9, 20, 883
Wet cup, 224

Wet return, 8, 513

Wind, winds

forces, 240, 247
due to stack effect, 240
natural draft equipment, 441
selection of, velocity, 263, 291

Window, windows

coefficients of transmission, 212
leakage, 241
solar radiation through, 309
ventilators, 658
Winter
air conditioning system, 743, 1221
comfort chart, 124
freezing equipment, 892
Wound rotor motor, 998
Wrought-iron pipe, 673
Wrought-steel pipe, 673

Y

Year-round air conditioning

system, 743, 1221
air flow in, 749, 1226
control methods, 744, 982
design procedure, 743, 789
equipment arrangement, 758
installation, 743, 1221
location of apparatus, 758, 1225
residential, 977
selection, 756, 1221

Z

Zero, absolute, 1

Zone, zones

control, 8, 87, 745, 979
evaporative regulation, 115
metabolic regulation, 114
thermal neutrality, 123
vaso-motor regulation, 114


Zoning, 585, 745, 977

control, 745, 977
hot water system, 585
reheat, 746
volume control, 745

CHAPTER 1

TERMINOLOGY

Glossary of Physical and Heating, Ventilating, Refrigerating and Air Conditioning Terms Used in the Text



Absolute Zero: The zero from which absolute temperature is reckoned. Approximately -273.15 Cor -459.67 F. These values were established by the Tenth General Conference on Weights and Measures, 1954.

Absorbent: A sorbent which changes physically or chemically, or both, during the sorption process.

Absorption: The action of a material in extracting one or more substances present in an atmosphere or mixture of gases or liquids; accompanied by physical change, chemical change, or both, of the sorbent.

Acceleration: The time rate of change of velocity, i.e., the derivative of velocity with respect to time. In the cgs system the unit of acceleration is the centimeter per (second) (second); in the fps system the unit is the foot per (second) (second), $a = \frac{dv}{dt}$

Acceleration Due to Gravity: The rate of gain in velocity of a freely falling body the value of which varies with latitude and elevation. The international gravity standard has the value of 980.665 cm per (sec) (sec) or 32.174 ft per (sec) (sec) which is the actual value of this acceleration at sea level and about 45 deg latitude.

Adiabatic: An adjective descriptive of a process such that no heat is added to, or taken from, a substance or system undergoing the process.

Adsorbent: A sorbent which does not change physically or chemically during the sorption process.

Adsorption: The action, associated with surface adherence, of a material in extracting one or more substances present in an atmosphere or mixture of gases and liquids, unaccompanied by physical or chemical change. Commercial adsorbent materials have enormous internal surfaces.

Aerosol: An assemblage of small particles, solid or liquid, suspended in air. The diameters of the particles may vary from 100 microns down to 0.01 micron or less, e.g., dust, fog, smoke.

Air Cleaner: A device designed for the purpose of removing airborne impurities such as dusts, gases, vapors, fumes and smokes. (Air cleaners include air washers, air filters, electrostatic precipitators and charcoal filters.)

Air Conditioning: The process of treating air so as to control simultaneously its temperature, humidity, cleanliness, and distribution to meet the requirements of the conditioned space.

Air, Dry: In psychrometry, air unmixed with, or containing no, water vapor.

Air, Saturated: A mixture of dry air and saturated water vapor, all at the same dry-bulb temperature.

Air, Standard: Air with a density of 0.075 lb per cu ft and an absolute viscosity of 0.0379×10^{-6} lb mass per (ft) (sec). This is substantially equivalent to dry air at 70 F and 29.92 in. (Hg) barometer.

Air Washer: An enclosure in which air is drawn or forced through a spray of water in order to cleanse, humidify, or dehumidify the air.

Anemometer: An instrument for measuring the velocity of a fluid.

Aspect Ratio: In air distribution outlets, the ratio of the length of the core of a grille, face or register to the width.

In rectangular ducts, the ratio of the width to the depth.

Atmospheric Pressure: The pressure of the atmosphere to be measured by means of the barometer. *Standard Atmospheric Pressure* or *Standard Atmosphere* is exactly 1,013,250 dynes per square centimeter by recent action of the Tenth General Conference on Weights and Measures (1954). It is approximately the pressure exerted by a column of mercury 76 cm high at standard gravitational acceleration, 980.665