



ZONOLITE

DIVISION W. R. GRACE & CO.

LIBBY, MONTANA

TELEPHONE 293-4131

E. D. Levick

March 27, 1969

01118



W. C. Nordin

Peter Kostic, R. J. Kujawa, J. D. Riggleman 03628030

The March 1969 dust counts for the Dry Mill Floors are tabulated below. The counts are exceptionally high because the 600 Fan was down while its cyclone was being replaced. The 600 Fan ventilates much of the dry mill equipment.

During the sampling period, the wind was 5-10 mph from the southwest, temperature was 46°F and the barometer read 30.37.

Floor	Dust Counts (mppcf)
6	50.4
5	38.0
4	56.8
3	59.9
Half Deck	141.6
2	74.7
1	46.4

WCNordin/jbg

W. C. Nordin

Dick :

Of course the reason is obvious but this is the worst I've seen. Since I keep a file of these reports please return to me.

Peter Kostic

15163038