Anniston, Alabama

April 9, 1968

This Copy For

W. F. Taffee
W. R. Haupt
R. A. Haydel
E. E. Smith

CEA 1430 AROCLOR EXPANSION
ANNISTON DESIGN QUESTIONS

R. W. Peterson
CED
General Offices

In answer to your following questions, we can put 4463 through the 5460 line and flaker feed tank and then to a drumming station, and all other solids also. Steel pipe is ok for the above.

I talked to E. E. Smith and they agreed (Smith-Haydel) that separate alarms for the eight tanks are not necessary and that one scan-alarm window for Hi-level will suffice.

J. C. Bradley

JCB:kd

0285239

TOWOLDMON0044192