

PLAINTIFF'S
EXHIBIT
WRG-617

August 11, 1971

Mr. Brad Dixon
Ed Beiting & Associates
1002 Monmouth Street
Newport, Kentucky 41071

Re: Mono-Kote
Comprehensive Rehabilitation Center
Thelma, Kentucky

Dear Mr. Dixon:

On July 12, 1971 I made a job site inspection of the Mono-Kote fire-proofing.

I met and discussed the job with the plaster's foreman Olvin Williams. We discussed age of the material and the application. I discussed proper sequence of mixing, proper amount of water to use, proper use of retarder and proper application to the steel.

I observed the material that had been installed. The material was soft and dusty and did not appear to have a good bond. The material also showed the use of excessive amounts of retarder.

I would recommend refusal of all material on job site. New, fresh material should be purchased.

Sincerely,

RR/au

Ron Ray
Sales Representative

cc: V. Monroe

THIS COPY FOR