



TABLE I
EMBARCADERO CENTER AIR SAMPLES

Sample Number	Area	Asbestos fibers	
		total f/ml	f/ml (> 5 μ)*
54 (A)	Spray operator's BZ	7.96	6.54
51 (A)	" " "	2.63	2.18
49 (A)	" " " (Held near back of head to protect face of filter)	3.56	3.18
47 (A)	Stage mover's BZ	1.86	1.53
2249 (B)	Area near spray (1-50 feet distant, some direct spray on filter)	0.030	0.028
2250 (C)	Background area, 43rd floor (air flow past spray-encrusted drapes)	0.020	0.016
56 (D)	Investigator's BZ	0.79	0.60
48 (E)	Mixing Operator's BZ	0.775	0.710

*Present tentative occupational threshold limit value of 5 f/ml is based on fibers greater than 5 micrometers in length.

000009