

TABLE 1. TYPICAL COMMERCIAL DESIGN ROOM CONDITIONS FOR SUMMER AVERAGE PEAK LOAD^a

TYPE OF INSTALLATION	DRY-BULB TEMP	WET-BULB TEMP	RELATIVE HUMIDITY PER CENT	GRAINS PER LB	EFFECTIVE TEMP
Deluxe Application.....	78	65.25	50	72.7	72.2
Normal Application.....	80	67	51	78.5	74.0
15 to 40 min Occupancy.....	82	68	49	80.0	75.3

^aValues in Table 1 are for peak load conditions. It is general practice to operate a system at approximately 76 F and 50 per cent relative humidity at other than peak load.

outside air temperature is usually in excess of 20 F. the *effective outside temperature* for normal heat transmission through walls and floors having substantial heat capacity is usually taken 5 to 10 deg below the design maximum outside temperature. For windows, however, the instantaneous value of outside temperature is used. This load is calculated in a manner similar to that described in Chapter 14 (except that flow of heat is reversed) by means of the formula:

$$H_t = AU (t_e - t) \quad (1)$$

where

H_t = heat transmitted through the material of wall, glass, floor, etc., Btu per hour.

A = net inside area of wall, glass, floor, etc., square feet.

t = inside temperature, Fahrenheit degrees.

t_e = effective outside temperature, Fahrenheit degrees.

U = coefficient of transmission of wall, glass, floor, etc. from Tables 4 to 18, Chapter 6, Btu per (hour) (square foot) (Fahrenheit degree difference in temperature).

Solar Heat Transmission

Calculations of the solar heat transmitted through walls and roofs are difficult because of periodic character of heat flow and time lag due to heat capacity of construction.

An illustration of the variation in radiation intensity on differently oriented surfaces is given in Fig. 1. The greater part of the radiation intensity is always direct radiation from the sun. However, during the time when the sun is shining, any surface receives radiation of a lower

TABLE 2. DESIGN DRY- AND WET-BULB TEMPERATURES, WIND VELOCITIES, AND WIND DIRECTIONS FOR JUNE, JULY, AUGUST, AND SEPTEMBER

STATE	CITY	DESIGN DRY-BULB	DESIGN WET-BULB	SUMMER WIND VELOCITY MPH	PREVAILING SUMMER WIND DIRECTION
Ala.	Birmingham	95	78	5.2	S
	Mobile	95	80	8.6	SW
Ariz.	Phoenix	105	76	6.0	W
Ark.	Little Rock	95	78	7.0	NE
Calif.	Los Angeles	90	70	6.0	SW
	San Francisco	90	65	11.0	SW
Colo.	Denver	95	64	6.8	S
Conn.	New Haven	95	75	7.3	S
	Wilmington	95	78	9.7	SW
Del.	Washington	95	78	6.2	S
Fla.	Jacksonville	95	78	8.7	SW
	Tampa	94	79	7.0	E

TABLE 2. DESIGN DRY- AND WET-BULB TEMPERATURES, WIND VELOCITIES, AND WIND DIRECTIONS FOR JUNE, JULY, AUGUST, AND SEPTEMBER (Concluded)

STATE	CITY	DESIGN DRY-BULB	DESIGN WET-BULB	SUMMER WIND VELOCITY MPH	PREVAILING SUMMER WIND DIRECTION
Ga.	Atlanta	95	76	7.3	NW
	Savannah	95	78	7.8	SW
Idaho.	Boise	95	65	5.8	NW
Ill.	Chicago	95	75	10.2	NE
	Peoria	95	76	8.2	S
Ind.	Indianapolis	95	76	9.0	SW
Iowa	Des Moines	95	77	6.6	SW
Kansas.	Wichita	100	75	11.0	S
Ky.	Louisville	95	76	8.0	SW
La.	New Orleans	95	79	7.0	SW
	Shreveport	100	78	6.2	S
Maine	Portland	90	73	7.3	S
Md.	Baltimore	95	78	6.9	SW
Mass.	Boston	92	75	9.2	SW
Mich.	Detroit	95	75	10.3	SW
Minn.	Minneapolis	95	75	8.4	SE
Miss.	Vicksburg	95	78	6.2	SW
Mo.	Kansas City	100	76	9.5	S
	St. Louis	95	78	9.4	SW
Mont.	Helena	95	67	7.3	SW
Nebr.	Lincoln	95	75	9.3	S
Nev.	Reno	95	65	7.4	W
N. H.	Manchester	90	73	5.6	NW
N. J.	Trenton	95	78	10.0	SW
N. Y.	Albany	92	75	7.1	S
	Buffalo	93	75	12.2	SW
	New York	95	75	12.9	SW
N. M.	Santa Fe	90	65	6.5	SE
N. C.	Asheville	90	75	5.6	SE
	Wilmington	95	79	7.8	SW
N. Dak.	Bismarck	95	73	8.8	NW
Ohio.	Cincinnati	95	78	6.6	SW
	Cleveland	95	75	9.9	S
Okla.	Oklahoma City	101	76	10.1	S
Ore.	Portland	90	65	6.6	NW
Pa.	Philadelphia	95	78	9.7	SW
	Pittsburgh	95	75	9.0	NW
R. I.	Providence	93	75	10.0	NW
S. C.	Charleston	95	80	9.9	SW
	Greenville	95	76	6.8	NE
S. Dak.	Sioux Falls	95	75	7.6	S
Tenn.	Chattanooga	95	77	6.5	SW
	Memphis	95	78	7.5	SW
Texas.	Dallas	100	78	9.4	S
	El Paso	100	69	6.9	E
	Galveston	95	80	9.7	S
	Houston	95	78	7.7	S
	San Antonio	100	78	7.4	SE
Utah	Salt Lake City	92	63	8.2	SE
Vt.	Burlington	90	73	8.9	S
Va.	Norfolk	95	78	10.9	S
	Richmond	95	78	6.2	SW
Wash.	Seattle	85	65	7.9	S
	Spokane	90	65	6.5	SW
W. Va.	Parkersburg	95	75	5.3	SE
Wis.	Madison	95	75	8.1	SW
	Milwaukee	95	75	10.4	S
Wyo.	Cheyenne	95	65	9.2	S