



Interoffice Communication

To Jim Barton
From Alton Reeves
Date September 18, 1978
Subject VAPOR RELEASE

On the 10th of September at 0710 a.m., Panel operator Steve Kilgore was venting the inert from 742 reactor over into the recovery unit. The gasket blew out on the bullseye on the recovery line. Walter West noticed the MSA unit had went off and also saw the vapor flowing from the bullseye and recovery area. Walter then notified Steve Kilgore of the blow out on his radio. Steve then sounded the vapor alarm, told the location of the release. I then went to the area with a Scott Air pack and isolated the bullseye. I then waited a few minutes and then clsoed off the deluge. water. I then checked the area for high vent vapor using the HNU. Did not detect any. Had Steve sound the all clear alarm. Called maintenance in to replace the gasket. No one got exposed to VCM.

Alton Reeves
Shift Supervisor

tap

c: CLM, ELK, AHS