Case: 49182-3

PLAINTIFF'S EXHIBIT

SWB-118

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

March 28, 1980

Mr. John D. Ludwig
New England Telephone Company
185 Franklin Street
Room 1501
Boston, Massachusetts 02107

Dear John:

The bulk sample you mailed to me labeled "baseboard heating ductwork at 225 Franklin Street, Boston", has been analyzed for asbestos. The major chrystalline component of this sample, as seen by x-ray diffraction, is chrysotile asbestos. The relative condition of the material as to whether or not it is breaking down cannot be evaluated. This should be done insitu.

If you have any questions regarding this analysis, please feel free to give me a call at (201) 582-7512.

David Rainer
Field Industrial Hygienist

MH-8685-DR-sma

Ref: 1152

Copy to
R. E. Finn, M.D. - NET

R. L. Beach - AT&T
N. J. DeCapua
J. M. Degen ← THIS COPY FOR
R. W. Stone, M.D.

W. J. Schreibeis
G. M. Wilkening

003601

CONFIDENTIAL