



JAMES F. WRIGHT
EXECUTIVE DIRECTOR

Called NYH on 6/29/77

DELAWARE RIVER BASIN COMMISSION
P. O. BOX 7360
WEST TRENTON, NEW JERSEY 08628
(609) 883-9500

JUN 29 1977

June 28, 1977

HEADQUARTERS LOCATION
25 STATE POLICE DRIVE
WEST TRENTON, N J

Mr. J. P. Sandstedt
Manager of Environmental Engineering
Tenneco Chemicals, Inc.
Post Office Box 365
Piscataway, New Jersey 08854

Dear Mr. Sandstedt:

SUBJECT: Tenneco Chemicals, Burlington Plant
DRBC Docket No. D-75-66

This is in reply to your May 31, 1977, letter advising us that more stringent emission limitations may require the incineration of vinyl chloride in various exhaust streams and that incinerator stack scrubber wastewater will increase total dissolved solids in the plant effluent. You estimate that TDS concentrations will increase to about 400 mg/l.

If your estimate of the TDS increase is correct, the effluent will continue to meet applicable standards and no further action by the Delaware River Basin Commission will be required.

Sincerely,


Herbert A. Howlett
Chief Engineer

COLORITE 018604