

**Bell Laboratories**

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

July 22, 1981

Alice Mignone
Southern New England Tel. Co.
195 Church St., 9th Floor
New Haven, CT 06506

PLAINTIFF'S EXHIBIT

SWB-195

Dear Alice:

The three dust samples (61381-1, 2, 3) you sent us from asbestos removal in the basement boiler room of 300 George Street, New Haven, Connecticut have been analyzed for asbestos per your request. The fourth dust sample (61581-4) was analyzed gravimetrically by Occupational Health Services, a Division of American Can Company. The three asbestos air samples were analyzed according to National Institute of Occupational Health and Safety guidelines. The results are based on your data and the analytical report as follows:

Sample	Time(min)	Vol(L)	Flow Rate (Lpm)	Fibers/fd*	Fibers/cc	Total dust (mg/m ³)
61381-1-AMM	360	698	1.94	101.5/55	0.2	-
-2	270	540	2.0	22.5/100	0.2	-
-3	-	-	-	7.5/100	-	-
61581-4-AMM	360	621	1.94	-	-	2.74

(*Microscopic Field area of 0.011 mm².)

Sample (61381-1) exceeds the OSHA medial surveillance guideline for asbestos at 0.1 fibers/cc (29 CFR 1910.1001). None of the asbestos samples exceed the OSHA PEL of 2 fibers/cc of air. The total nuisance dust sample is below the PEL of 10 mg/m³.

If you have any questions, please advise.

Sincerely,

Patricia C. Payne

Patricia C. Payne

Ref: 1333-(01, 02, 03, 04)

Copy to
See next page

CONFIDENTIAL

003851

Alice Mignone - 2

Copy to

W. D. Luty - SNE

F. L. Provato, M.D.

N. J. DeCapua - AT&T

J. M. Degen

R. W. Stone, M.D.

W. J. Schreiber

G. M. Wilkening

CONFIDENTIAL

003852