


Abex

An IC Industries Company

Abex Corporation—Medical Department
Industrial Hygiene Analytical Laboratory
4550 West 26th Street
Chicago IL 60623
312/521-3210

TO: Mr. Ralph Smoot
Safety Director
Appleton Electric Company
1701 West. Wellington Avenue
Chicago, IL 60657

Date 8/6/84 INVOICE NO. **H-97** 84- 0266

| DESCRIPTION OF SERVICES | UNIT PRICE | TOTAL |
|---|---|---|
| REFERENCE REQUEST NUMBER: 577 | | |
| 1 Bulk Asbestos Analysis | $ 35.00 | $ 35.00 |
| CHECKS PAYABLE TO:<br>ABEX CORPORATION<br>SIX LANDMARK SQUARE<br>P. O. BOX 10268<br>STAMFORD, CT. 06904-2268<br>ATTN: TREASURER | | |
| AMOUNT DUE | | $ 35.00 |

Please contact us immediately for any corrections or further information.

Terms. Net Cash
Make checks payable to
ABEX CORPORATION,
Medical Dept.

Prepared by R. S. Suga, Manager

APS-8068

PETROGRAPHIC ANALYSIS FOR ASBESTOS
(Type and Weight % of Asbestos)

| Sample | Asbestos present | | Chrysotile | Amosite | Anthophyllite | Tremolite Actinolite | Crocidolite | Other Fibrous Constituents | Homogeneous | | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | Yes | No | | | | | | | Yes | No | |
| ;iling Panel | | + | | | | | | mineral wool 98 | + | | |
| | | | | | | | | cellulose trace | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

FGL 1194

Fay Goldblatt Laboratories, Inc , 910 W Clayton St , Waukegan, IL 60085

**Fay Goldblatt Laboratories, Inc.**

910 West Clayton Street • Waukegan, Illinois 60085 • (312) 249-1745

July 24, 1984

Mr. R. S. Suga
Abex Corporation
485 Frontage Road
Burr Ridge, IL 60521

Dear Mr. Suga:

Thank you for the ceiling panel which you sent for asbestos fiber analysis under analysis request number 0353. I have examined it by both polarized light microscopy and dispersion staining. The amounts of fibrous components found are given on the enclosed summary report form as estimated percentages by weight; quantities may be expected to vary depending on sample homogeneity.

The sample will be discarded after two weeks if I do not hear from you further. The enclosed invoice covers the costs of this nalysis. If there are any questions regarding this report, or if I may be of service in the future, please feel free to call.

Sincerely,

Fay Goldblatt

FGL 1194
encl.

Fay Goldblatt
Principal Microscopist



SPM 1656

Abex

An IC Industries Company

Abex Corporation—Medical Department
Industrial Hygiene Analytical Laboratory
4350 West 26th Street
Chicago, IL 60623
312/521-3240

## ANALYSIS REQUEST NO. 0353

Name
Title
Firm
Address
Tel. No.

P. O. #
Date Sample Taken
Date Received by Lab
Date Completed
Temp.(°F) Pressure (In Hg)

| FIELD NO. | SAMPLE VOL.(L) | ANALYZE FOR | LAB. NO. | RESULTS |
|---|---|---|---|---|
| | | | 1583 | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Comments:

Authorization Signature

American Industrial Hygiene Association Accreditation
License: IL State P.H. #0017061
CLIA-12-1067

APS-0067

Appleton
ELECTRIC COMPANY
1701 W Wellington Av • Chicago, IL 60657 • (312) 327-7200

July 16, 1984

Mr. Reggie Suga
Abex Medical
485-Frontage Road
Burr Ridge, Illinois 60521

Dear Reggie:

This material was removed from a ceiling panel in our Production Engineering department.

I would like to know if it contains asbestos. If it does - what amount?

Sincerely,

Ralph Smoot
Safety Director

RS/egh

Lab # 1563

Bulk Asbest
F. Goldblatt

APPLETON ELECTRIC COMPANY
SUBSIDIARY OF EMERSON ELECTRIC CO.

SPIM 1880

Abex

An IC Industries Company

Abex Corporation—Medical Department
Industrial Hygiene Analytical Laboratory
4550 West 26th Street
Chicago, IL 60623
312/521-3210

TO: Mr. Ralph Smoot
Safety Director
Appleton Electric Company
1701 W. Wellington Ave.
Chicago, IL 60667

## ANALYSIS REPORT

Sample received _____ Sample analyzed _____ Job No. 0577

Report Date 8/7/84 Request/P.O.# per Mr. Smoot

RESULTS

| Sample No. | ANALYSIS REQUESTED | Asbestos % | Mineral Wool % | Cellulose % | | |
|---|---|---|---|---|---|---|
| 1 | Ceiling Panel | 0 | 98 | trace | | |

[illegible]
ABEX CORPORATION
SIX LANDMARK SQUARE
P. O. BOX 10266
STAMP [illegible] 06904-2268
ATTN [illegible]

Comments: Polarized Light Microscopy and Dispersion Staining

[illegible] immediately [illegible] further information.

Submitted by: [signature]
R. S. Suga, Manager

American Industrial Hygiene Association Accreditation
License: IL State P.H. 90017061
CLIA-12-1067

APL-8086

SPM 1981