

FILE NAME: Packings and Gaskets (PAG)

DATE: 1985 June 19

DOC#: PAG045

DOCUMENT DESCRIPTION: Health & Safety Committee Meeting

Crown Central Petroleum

Health & Safety Committee Meeting
June 19, 1985

Present were:

Union

L. Darby *J. Darby*
C. Kitchens *Charles Kitchens*
K. Blackburn *K. Blackburn*

Management

K. Roy *K. Roy*
W. O. Stewart *W. O. Stewart*
J. K. Drick *J. K. Drick*

Items noted during the inspection of the Udex on May 15, 1985, have been corrected or have work orders submitted.

Mr. Darby asked the status of the Severe Weather Plan, Mr. Drick replied it was to Mr. Robinson. He also asked about the hot water heater for the Operators House at the Dock; Mr. Roy said he would look into this.

Mr. Darby asked what action was being taken to clean up the Lead spill and where was the contaminated fill being taken to. Mr. Drick said the contaminated dirt was being dug out and taken to the land fill area at the North side of the Refinery.

Mr. Darby stated that in the Warehouse there is a roll of asbestos gasket material and numerous gaskets that contain asbestos; what action is being taken to dispose of the asbestos gaskets and material. W. O. Stewart said he is phasing out the asbestos gaskets and will see to it that the roll of of gasket material is removed to land fill.

Mr. Blackburn asked Mr. Roy to explain the problem with the absence of the top relief valve on Alky 2 Depropanizer and when will the valve be replaced. Mr. Kitchens then asked when an emergency dump valve will be installed on Alky 2 similar to the one on Alky 2. Mr. Roy replied that in both cases the work will be done when the units again come down, in the meantime he feels it is safe to operate the unit as it is.

Mr. Blackburn asked if Mr. Stewart would make his supervisors aware that the Tyvek coveralls do not "breathe" and in periods of hot weather this should be taken into consideration and regular work rests be given to employees to allow them to cool off. Mr. Stewart said he would so inform his supervisors.

JAD:ds
6/26/85

CCR 0000661

EXHIBIT

Assembly 92
11-1-08 GNC