

of pipe by welding sometimes warrants using lighter wall thicknesses. The considerations governing pipe wall thickness and its relation to joint design are covered in the *American Standard Code for Pressure Piping*, A.S.A. B31.1-1942, see Section 122. Standard schedules of pipe thicknesses are contained in the *American Standard for Wrought-Iron and Wrought-Steel Pipe*, A.S.A. B36.10, which includes standard-weight and

TABLE 3. STANDARD DIMENSIONS AND WEIGHTS, AND TOLERANCES IN DIAMETER AND WALL THICKNESS FOR COPPER WATER TUBES*

(All tolerances in this table are plus and minus except as otherwise indicated)

STANDARD WATER TUBE SIZE, IN.	ACTUAL OUTSIDE DIAMETER IN.	AVERAGE OUT- SIDE DIAMETER		WALL THICKNESS IN.								THEORETICAL WEIGHT, LB PER FT		
		TOLERANCE, IN.		TYPE K		TYPE L		TYPE M		Type K	Type L	Type M		
		Annealed	Drawn Temper	Nominal	Tolerance	Nominal	Tolerance	Nominal	Tolerance					
1/8	0.250	0.002	0.001	0.032	0.003	0.025	0.0025	0.025	0.0025	0.085	0.068	0.068		
1/4	0.375	0.002	0.001	0.032	0.004	0.030	0.0035	0.025	0.0025	0.134	0.126	0.107		
3/8	0.500	0.0025	0.001	0.049	0.004	0.035	0.0035	0.025	0.0025	0.269	0.193	0.145		
1/2	0.625	0.0025	0.001	0.049	0.004	0.040	0.0035	0.028	0.0025	0.344	0.285	0.204		
5/8	0.750	0.0025	0.001	0.049	0.004	0.042	0.0035	0.030	0.0025	0.418	0.362	0.263		
3/4	0.875	0.003	0.001	0.065	0.0045	0.045	0.004	0.032	0.003	0.641	0.455	0.328		
1	1.125	0.0035	0.0015	0.065	0.0045	0.050	0.004	0.035	0.0035	0.839	0.655	0.465		
1 1/4	1.375	0.004	0.0015	0.065	0.0045	0.055	0.0045	0.042	0.0035	1.04	0.884	0.682		
1 1/2	1.625	0.0045	0.002	0.072	0.005	0.060	0.0045	0.049	0.004	1.36	1.14	0.940		
2	2.125	0.005	0.002	0.083	0.007	0.070	0.006	0.053	0.006	2.06	1.75	1.46		
2 1/2	2.625	0.005	0.002	0.095	0.007	0.080	0.006	0.065	0.006	2.93	2.48	2.03		
3	3.125	0.005	0.002	0.109	0.007	0.090	0.007	0.072	0.006	4.00	3.33	2.63		
3 1/2	3.625	0.005	0.002	0.120	0.008	0.100	0.007	0.083	0.007	5.12	4.29	3.53		
4	4.125	0.005	0.002	0.134	0.010	0.110	0.009	0.095	0.009	6.51	5.38	4.66		
5	5.125	0.005	0.002	0.160	0.010	0.125	0.010	0.109	0.009	9.67	7.81	6.66		
6	6.125	0.005	0.002	0.192	0.012	0.140	0.010	0.122	0.010	13.9	10.2	8.92		
8	8.125	0.006	+0.002 -0.004	0.271	0.016	0.200	0.014	0.170	0.014	25.9	19.3	16.5		
10	10.125	0.008	+0.002 -0.006	0.338	0.018	0.250	0.016	0.212	0.015	40.3	30.1	25.6		
12	12.125	0.008	+0.002 -0.006	0.405	0.020	0.280	0.018	0.254	0.016	57.8	40.4	36.7		

* From Standard Specifications for Copper Water Tube of the American Society for Testing Materials A.S.T.M. Designation B88-41.

NOTE 1:—For copper gas and oil burner tubes, the tolerances shown above for various wall thicknesses (type K) apply irrespective of diameter.

NOTE 2:—For tubes other than round no standard tolerances are established. These tolerances do not apply to condenser and heat exchanger tubes.

extra-strong thicknesses in Schedules 40 and 80, respectively, and eight other schedules of varying wall thickness to provide for different service conditions. Dimensions and other useful data for Schedules 30 and 40 pipe are given in Table 1. Table 2 from A.S.T.M. Specifications A53 and A120 combines the schedule thicknesses of A.S.A. B36.10 and the old series designations.

Standard-weight pipe is generally furnished with threaded ends in random lengths of 16 to 22 ft, although when ordered with plain ends, 5 per cent may be in lengths of 12 to 16 ft. Five per cent of the total number of lengths ordered may be *joints* which are two pieces coupled together.

Extra-strong pipe is generally furnished with plain ends in random lengths of 12 to 22 ft, although 5 per cent may be in lengths of 6 to 12 ft.

In addition to IPS copper pipe, several varieties of copper tubing are in use with either flared or compression couplings or soldered joints. Dimensions of copper water tubing intended for plumbing, underground water service, fuel-oil lines, gas lines, etc., have been standardized by the U. S. Government and the American Society for Testing Materials. There are

TABLE 4. THERMAL EXPANSION OF PIPE IN INCHES PER 100 FT*

(For superheated steam and other fluids refer to temperature column)

SATURATED STEAM			ELONGATION IN INCHES PER 100 FT FROM -20 F UP				SATURATED STEAM		ELONGATION IN INCHES PER 100 FT FROM -20 F UP			
Vacuum Inches of Hg.	Pressure Psig	Tem- perature Fahren- heit Degrees	Cast- Iron Pipe	Steel Pipe	Wrought- Iron Pipe	Copper Pipe	Pressure Psig	Tem- perature Fahren- heit Degrees	Cast- Iron Pipe	Steel Pipe	Wrought- Iron Pipe	Copper Pipe
		-20	0	0	0	0	2.5	220	1.634	1.852	1.936	2.720
		0	0.127	0.145	0.152	0.204	10.3	240	1.780	2.020	2.110	2.960
		20	0.255	0.293	0.306	0.442	20.7	260	1.931	2.183	2.279	3.189
		40	0.390	0.430	0.465	0.655	34.5	280	2.085	2.350	2.465	3.422
29.39		60	0.518	0.593	0.620	0.888	52.3	300	2.233	2.519	2.630	3.665
28.89		80	0.649	0.725	0.780	1.100	74.9	320	2.395	2.690	2.800	3.900
27.99		100	0.787	0.898	0.939	1.338	103.3	340	2.543	2.862	2.988	4.145
26.48		120	0.926	1.055	1.110	1.570	138.3	360	2.700	3.029	3.175	4.380
24.04		140	1.051	1.209	1.265	1.794	180.9	380	2.859	3.211	3.350	4.628
20.27		160	1.200	1.368	1.427	2.008	232.4	400	3.008	3.375	3.521	4.870
14.63		180	1.345	1.528	1.597	2.255	293.7	420	3.182	3.566	3.720	5.118
6.45		200	1.495	1.691	1.778	2.500	366.1	440	3.345	3.740	3.900	5.358

* From *Piping Handbook*, by Walker and Crocker. This table gives the expansion from -20 F to the temperature in question. To obtain the amount of expansion between any two temperatures take the difference between the figures in the table for those temperatures. For example, if a steel pipe is installed at a temperature of 60 F and is to operate at 300 F, the expansion would be 2.519 - 0.593 = 1.926 in.

three standard wall-thickness schedules of copper water tubing classified in accordance with their principal uses as follows:

Type K—Designed for underground services and general plumbing service.

Type L—Designed for general plumbing purposes.

Type M—Designed for use with soldered fittings only.

In general, Type K is used where corrosion conditions are severe, and Types L and M where such conditions may be considered normal as, for instance, in heating work. Types K and L are available in both hard and soft tempers; Type M is available only in hard temper. Where flexibility is essential as in hidden replacement work, or where as few joints as possible are desired as in fuel-oil lines, the soft temper is commonly used. In new or exposed work copper pipe of a hard temper is generally used. All three classes are extensively used with soldered fittings.

Standard dimensions, weights, and diameter and wall-thickness tolerances for these classes of copper tubing are given in Table 3. Copper pipe is also available with dimensions of steel pipe.

Refrigeration lines used in connection with air conditioning equipment also employ copper tubing extensively. For refrigeration use where tubing absolutely free from scale and dirt is required, bright annealed copper