



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5
77 WEST JACKSON BOULEVARD
CHICAGO, ILLINOIS 60604**

DATE: NOV 07 2018
SUBJECT: CLEAN AIR ACT INSPECTION REPORT
Galesburg Cottage Hospital, Galesburg, Illinois
FROM: Vicky Mei, Environmental Engineer
AECAB (IL/IN)
THRU: Nathan Frank, Section Chief
AECAB (IL/IN)
TO: File

BASIC INFORMATION

Facility Name: Galesburg Cottage Hospital

Facility Location: 695 Kellogg St., Galesburg, Illinois

Date of Inspection: October 24, 2018

EPA Inspector(s):

1. Vicky Mei, Environmental Engineer

Other Attendees

1. Cassie Cirimotich, Chief Quality Officer, Galesburg Cottage Hospital
2. Chad Schmidgall, Facilities Director, Galesburg Cottage Hospital

Contact Email Address: chad_schmidgall@quorumhealth.com

Purpose of Inspection: General Clean Air Act Inspection

Facility Type: Hospital

Arrival Time: 2:30PM

Departure Time: 2:55PM

Inspection Type:

- ☒ Unannounced Inspection
☐ Announced Inspection

OPENING CONFERENCE

- ☒ Credentials Presented
☒ CBI warning to facility provided

The following information was obtained verbally from Mr. Schmidgall and Ms. Cirimotich unless otherwise noted.

Company Ownership: The facility's Clean Air Act permit was listed under the name of its former owner, Galesburg Hospital Corporation, at the time of the inspection. Ownership of the facility was transferred in 2005 and again in 2016 to most recently Quorum Health Corporation.

Process Description:

The permitted incinerator and ethylene oxide sterilizers have not been in operation for over 10 and 7 years respectively. The facility is currently in the process of submitting an updated permit application to Illinois Environmental Protection Agency. The 3 natural gas boilers were installed in the 1970's and are inspected annually. Two of the boilers have upgraded burners. An underground diesel storage tank is available as backup and the diesel is tested annually.


TOUR INFORMATION


EPA toured the facility: No

Photos and/or Videos: were not taken during the inspection.

Field Measurements: were not taken during this inspection.

SIGNATURES

Report Author:  Date: 10/29/2018

Section Chief:  Date: 11/7/18