



PLAINTIFF'S EXHIBIT

SWB-130

Bell Laboratories

600 Mountain Avenue
Murray Hill, New Jersey 07974
Phone (201) 582-3000

December 10, 1980

Theodore R. Inge, Jr.
10-4C-232
195 Broadway Corporation
P.O. Box 2016
New Brunswick, NJ 08903

Dear Mr. Inge:

The insulation sample you sent from the basement chiller room in 430 Mountain Avenue has been analyzed for asbestos by Walter C. McCrone Associates, Inc. - a microscopy laboratory. The technique used was polarized light microscopy with dispersion staining. The sample consisted of approximately equal quantities of chrysotile asbestos and glass wool.

If you have any questions about this analysis please let me know.

C. P. Lichtenwalner


MH-8691-CPL-ds

Ref 1235

Copy to
R. J. Gonzalez - 195 Broadway

N. J. DeCapua - AT&T
J. M. Degen
R. W. Stone, M.D.

W. J. Schreibeis
G. M. Wilkening



CONFIDENTIAL

003629