

1984
AREAS ABOVE 90 DECIBELS

P-100's	93
COOLING TOWER PUMPS	92
K-125	90-94
K-320	89-98
UNDER HIGHRISE BY C-110	90-93
K-350's	91
E-250 & E-255	91
E-212	92-96
HEAVY BOILER BLOWDOWNS	98
3RD FLOOR OXY, TRAIN I	89-96
TRAIN II	96
TOP FLOOR OXY, TRAIN I	91
TRAIN II	96
P-263A MOTOR	95
STEAM LETDOWN STATION BY C-140	96
K-400	96-97
BETWEEN D-111 PUMPS (P-113 A&B)	88-92
WEST END FAN DECK BY FEED TANKS	90-94
E-101	90-83
E-102	88-92