PLAINTIFF'S
EXHIBIT
KN-340

June 15th, 1970.

Mr. Lee C. Jenne
Keene Corporation
Sound Control Division
U. S. #1
Princeton, N. J. 08540.

Dear Lee-

I am forwarding invoice covering cost of repairing a KDB job done on a metal building for the Mosher Steel Company, in Dallas. First report of fallout was on March 4th and material was off in five different locations. Repairs were made on March 9th. On March 11th another cal was received from the customer to the effect that fallout had occurred in two more spots. At this point I suggested that we be in no hurry to make these repairs but wait to see how much more would come off. When repairs were made on June 10th & 11th material was off in nine spots but no fallout had occurred for several weeks.

This building is a Texas size toilet (15 Holer) and change house for plant workers. The results obtained here were so outstanding that the company has included the Powerhouse and a large warehouse in their 1970 budget. No KDB, however.

I still have not repaired the ceiling of the Automatic Products Company, in Garland, another KDB failure. On the last inspection material was off in fifteen different spots, none larger than a small desk. This shop contains 15 Automatic screw machines and on the last inspection no material was off over these machines. I plan to make repairs to this job this month.

Yours very truly,

T. S. Chenoweth