



REGION 6

DALLAS, TX 75270

January 16, 2024

TRANSMITTED VIA E-MAIL:

Shayne Hollier
Cajun Heritage RV Park Water System
2026 Atchafalaya River Highway
Breau Bridge, LA 70517
holliershayne@gmail.com

Re: PWS ID Number: LA2099010, Cajun Heritage RV Park Water System
Administrative Order: Docket Number: SDWA-06-2023-1302

Dear Mr. Hollier,

Enclosed is an Administrative Order (Order) issued to you (Respondent) for violations of the Safe Drinking Water Act (Act), 42 U.S.C. § 300f *et seq.*, and its implementing regulations, 40 C.F.R. Part 141. The Environmental Protection Agency (EPA), Region 6 finds that Respondent owns or operates a public water system identified in the Order and is therefore subject to these regulations. The EPA requests that you immediately confirm receipt of this letter and the attached Order by a response e-mail to young.craig@epa.gov. This Order is effective immediately upon receipt.

This Order does not assess a monetary penalty; however, it does require compliance with the Ground Water Rule (GWR) treatment technique requirements pursuant to 40 C.F.R. §§ 141.403 and 141.404. The Respondent failed to correct significant deficiencies identified in a sanitary survey conducted by the Louisiana Department of Health (LDH) on April 19, 2022.

If you need assistance, or have questions regarding the Order, please contact Craig Young, of my staff, at (214) 665-2275.

Sincerely,

A handwritten signature in blue ink that reads "Cheryl T. Seager".

Digitally signed by CHERYL
SEAGER
Date: 2024.01.16 16:20:37 -06'00'

Cheryl T. Seager, Director
Enforcement and
Compliance Assurance Division

ENCLOSURES

1. LA2099010 Cajun Heritage GWR AO
2. Cajun Heritage RV Park Water System LA2099010 SS 04192022
3. Cajun Heritage RV Park LA2099010 TT45 August 2022

ec: staceyhollier@gmail.com
unitedwatersystem@centurytel.net
caryn.benjamin@la.gov
lthibodeaux@stmartinparish.net

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6

In the Matter of

Shayne Hollier,

Respondent

PWS ID# LA2099010

§
§
§
§
§
§
§
§
§
§
§
§

Docket No. SDWA-06-2023-1302

ADMINISTRATIVE ORDER

STATUTORY AUTHORITY

The following findings are made, and Order issued, under the authority vested in the Administrator of the United States Environmental Protection Agency (EPA), by Section 1414(g) of the Safe Drinking Water Act (SDWA or the Act), 42 U.S.C. § 300g-3(g). The Administrator delegated the authority to issue this Order to the Regional Administrator of EPA Region 6, who delegated such authority to the Director of Enforcement and Compliance Assurance Division.

FINDINGS

1. Shayne Hollier (Respondent) is a “person,” as defined by Section 1401(12) of the Act, 42 U.S.C. § 300f(12).
2. At all times relevant to the violations alleged herein (relevant time period), Respondent owned or operated the Cajun Heritage RV Park Water System, a public water system (PWS), as defined by Section 1401(4) of the Act, 42 U.S.C. § 300f(4), located in Breaux Bridge, St. Martin Parish Louisiana, (facility), designated as PWS number LA2099010.
3. During the relevant time period, Respondent’s PWS was a “non-community water system”, as defined by Section 1401(16) of the Act, 42 U.S.C. § 300f(16). Respondent’s PWS is subject to the requirements of the Act and its implementing regulations, 40 C.F.R. Part 141.

4. Systems that have at least 15 service connections or regularly serve an average of at least 25 individuals per day at least 60 days per year are subject to the requirements of the Act, 42 U.S.C. § 300g-1, and its implementing regulations, 40 C.F.R. Part 141. See 42 U.S.C. § 300f and 40 C.F.R. § 141.2.
5. As a PWS and a “supplier of water,” the Cajun Heritage RV Park Water System serves approximately 450 people with 150 service connections.
6. During the relevant time period, Respondent’s PWS was subject to the requirements of the Ground Water Rule (GWR) as set forth in 40 C.F.R. §§ 141.400 – 141.405.
7. The Louisiana Department of Health (LDH) administers the Public Water Supply Supervision Program in Louisiana pursuant to Section 1413 of the Act, 42 U.S.C. § 300g-2. LDH has primary enforcement responsibility for the GWR. LDH and EPA have consulted regarding this Order, and it was agreed that EPA would initiate this enforcement action.
8. Pursuant to 40 C.F.R. § 141.401, a sanitary survey inspection was conducted by LDH on November 12, 2018 and April 19, 2022, to evaluate the source of water supply, pumps and pumping facilities, and management and operator qualifications. The following significant deficiencies were noted by LDH:
 - a. Failure to submit plans and specifications to LDH for approval as part of permit to operate the PWS as a total chlorine (chloramine) system for Well #2 in accordance with LAC 51:XII.319.D.1 and 105.A-B,D.
 - b. Failure to maintain a 24-mesh corrosion resistant screen on Well #2’s casing vent to prevent the entrance of contaminants in accordance with LAC 51:XII.319.D.7.
 - c. Failure to have all RV sites equipped with a dual check valve assembly to protect the water supply from potential contamination.
9. In a letter dated November 30, 2018 and May 3, 2022, LDH notified Respondent of the significant deficiencies and required Respondent to correct the significant deficiencies and provide written

notification to LDH of the completed corrective actions with ninety (90) days of receipt of the letter. Respondent violated 40 C.F.R. § 141.403 by failing to address the significant deficiencies.

10. Pursuant to 40 C.F.R. § 141.404(a), Respondent did not complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction, including State specified interim actions and measures, nor is Respondent in compliance with a State-approved corrective action plan and schedule. Failure to meet these requirements is a violation of the Ground Water Rule treatment technique requirements.
11. Pursuant to 40 C.F.R. § 141.203, PWSs must provide public notice of violations of treatment technique requirements as soon as practical, but no later than 30 days after the system learns of the violation.
12. In a letter dated August 5, 2022, LDH, notified the Respondent of the Ground Water Rule treatment technique requirement violation and of the requirement that Respondent provide public notice of the violation. Respondent failed to provide public notice of the treatment technique requirement violation in accordance with 40 C.F.R. § 141.203.

SECTION 1414(g) COMPLIANCE ORDER

Based on the foregoing findings and pursuant to the authority of Section 1414(g) of the Act, 42 U.S.C. § 300g-3(g), EPA orders that Respondent immediately take the following actions:

- A. Within thirty (30) days of receipt of this Order, Respondent shall address all significant deficiencies identified by LDH in the November 30, 2018 and May 3, 2022 letter and shall submit a report to EPA and LDH indicating what actions have been taken and how the deficiencies have been addressed. If Respondent is technically unable to correct all deficiencies within thirty (30) days of this Order, Respondent shall submit to EPA, with a copy to LDH, a proposed plan, including a schedule, to achieve compliance and address all identified deficiencies. The plan shall be submitted to EPA for review and approval within thirty (30) days of this Order.
- B. The reporting required by this Order must be provided by Respondent to EPA and LDH at the following addresses:

Mr. Craig Young
Water Resources Branch (6EN-WR)
Enforcement and Compliance Assurance Division
U.S. EPA, Region 6
1201 Elm Street, Suite 500
Dallas, TX 75270-2102
young.craig@epa.gov

And

Caryn Benjamin, P.E.
Deputy Chief Engineer - Enforcement
LDH-OPH, Engineering Services
628 N. Fourth Street
P.O. Box 4489
Baton Rouge, LA 70821
caryn.benjamin@la.gov
(225) 342-7499

GENERAL PROVISIONS

This Order is effective upon receipt by a representative of the PWS.


Respondent may seek federal judicial review of the Order pursuant to Chapter 7 of the Administrative Procedure Act, 5 U.S.C. §§ 701-706.

This Section 1414(g) Compliance Order does not constitute a waiver, suspension, or modification of the requirements of 40 C.F.R. Part 141 or other applicable federal and state requirements, which remain in full force and effect. Issuance of this Section 1414(g) Compliance Order is not an election by EPA to forego any civil or any criminal action otherwise authorized under the Act.

Violation of any term of this Section 1414(g) Compliance Order may subject the Respondent to an administrative civil penalty of up to \$47,061 under Section 1414(g) of the Act, 42 U.S.C. § 300g-3(g), or a civil penalty of not more than \$67,544 per day per violation, assessed by an appropriate United States District Court under Section 1414(g)(3)(A) of the Act, 42 U.S.C. § 300g-3(g)(3)(A).

January 16, 2024

Date


Digitally signed by
CHERYL SEAGER
Date: 2024.01.16
16:19:27 -06'00'

Cheryl T. Seager, Director
Enforcement and
Compliance Assurance Division