

TO: Plasterco, J. Crepeau
FROM: #151 Libertyville, C. D. Byers *CDB/BAH*
SUBJECT: Analysis of Insulation Sample, AR #1849

March 9, 1987

cc: #151, B. W. Ost
#176-5, F. P. May
#143, M. F. O'Toole
#176-5, J. R. Rabe
Plasterco, J. D. Barth
Plasterco, B. J. Bachman

A sample of insulation was received from you on March 3. The sample was observed using the stereobinocular microscope and analyzed by polarized light microscopy using dispersion staining. The results show that the sample contains chrysotile asbestos.

CDB/bah

CB012 2489