Monsanto

FROM (NAME & LOCATION): R. McEntire

DATE: January 10, 1972

SUBJECT:

REFERENCE:

cc: R. Blowers
H. Horner
M. Campbell

TO: W. Engman
C. Buckley
J. Munoz
R. McCutchan
A. Rasmussen

COMPANY CONFIDENTIAL

The amount and type of PCB obtained in recent water samples are reported below. Results are in parts per billion (ppb) unless otherwide noted.

Log No.	Date	Sample Description	(ppb) PCB	Type
1	1/2/72	2-A fast pump	16	1221
			20	1242
			7	1254
2	1/2	2-A Comp	23	1221
			29	1242
			5	1254
3	1/2	Inc. overflow	48 ppm	1242
			10 ppm	1260
4	1/2	1-B comp	unable to det.	
5	1/2	1-B comp.fast	80	1242
			42	1260
6	1/2	2-C	unable to det.	
7	1/2	4-Z	92	1221
			109	1242
			50	1260
8	1/2	WTP Inf.	14	1221
			23	1242
			13	1254
9	1/2	WTP eff.	10	1242
			8	1254
10	1/2	WTP inf.-fast	29	1242
			14	1260
11	1/2	Inc. mix	unable to det.	
12	1/3	WTP #1	70	1221
			33	1242
			11	1260
13	1/3	WTP #2	46	1221
			18	1242
14	1/3	WTP #3	107	1221
			30	1242
			11	1260
15	1/3	WTP #4	131	1221
			111	1242
			23	1260
16	1/3	WTP #5	403	1221
			89	1242
			69	1260

MONS 098827

Log No.	Date	Sample Description	(ppb) PCB	Type
17	1/3/72	Scrubber eff.	274	1242
			162	1260
18	12/30/71	Scrubber eff.	2	1242
			3	1260
19	1/3	Inc. mix	unable to det.	
20	1/6	Scrubber eff	23	1248
			44	1260
21	1/5	Inc. overflow	18 ppm	1242
			15 ppm	1260
22	1/5	WTP Inf.	26	1221
			23	1242
			12	1254
23	1/5	WTP Eff. spec. flipflop	99	1242
			45	1260
24	1/5	WTP eff.	16	1242
			7	1254
25	1/5	1-B comp.	17	1248
			18	1260
26	1/5	2-A Comp	52	1242
			11	1254
27	1/5	2-G comp.	17	1242
			17	1260
28	1/5	4-Z comp.	85	1242
			37	1254

E.McEntire

dy